

From: Cherry, Brian K
Sent: 9/8/2011 5:33:28 PM
To: 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov); Jacobson, Erik B (RegRel)
(/O=PG&E/OU=Corporate/cn=Recipients/cn=EBJ1)
Cc:
Bcc:
Subject: Fw: Update; System Disturbance San Diego

We are fine here in PG&E's service territory. No outages.

From: Lemler, Gregg
Sent: Thursday, September 08, 2011 05:23 PM
To: Cherry, Brian K
Cc: Williams, Geisha
Subject: Fw: Update; System Disturbance San Diego

FYI. Gregg

From: Armstrong, Dave (ET)
Sent: Thursday, September 08, 2011 04:35 PM
To: Trans-Sub Update
Subject: FW: Update; System Disturbance San Diego

At 1538 A loss of 500kV lines in the APS area created a disturbance resulting in over 4000MW of load lost in CAISO, IID, CFE. Restoration efforts are in affect Frequency went to 60.159. Frequency currently stable at 60.02.

PG&E System load; 17,079

David A Armstrong
Senior Dispatcher
Electric System Dispatch Vacaville
707-449-6767

From: Armstrong, Dave (ET)
Sent: Thursday, September 08, 2011 3:48 PM
To: Trans-Sub Update
Subject: System Disturbance San Diego

1539 CAISO reports San Diego Electrical system has blacked out. Cause unknown. PG&E system is stable. DCPD Units are stable.

System load 16865 MW

David A Armstrong
Senior Dispatcher
Electric System Dispatch Vacaville
707-449-6767