

Circuit 062462225, GRAND ISLAND 2225
Type Unplanned
Customers CESO 520 CEMO 1774 Initial 2294
Active NO
Interval Sustained
EquipID OCB
Equipment Type Circuit Breaker
Equipment Condition Conductor, Overhead, On Ground
Crew Notified Time 09/12/11 10:05
Equipment Address SUBSTATION
Fault Location Redacted
Previous Switching Details
Action Description
Cause Equipment Failure/Involved, Other
Multi Damage Location No
Counter Read 69
Outage Level Distribution Circuit
FNL 09/12/11 09:55
End Date 09/12/11 13:52

District Solano
Customer Minutes Sustained 55658 Momentary 3548 C
Weather Rain,Lightning,32-90 F
Fault Type Line to Ground
Action Required No
Construction Type OH
OIS Outage# 405519
Targets A B GRD T SET A RLY
Supervisor Notified VACAVILLE CLERK Redacted

No Access Reason
of Operations 3
Created By RGP0
Last Updated By RGP0
Reviewed By
Reviewed By Date

Actions

Date	Description	Customers Restored	Customers Out	Minutes Out	Customer Minutes
09/12/11 09:55	GRAND ISLAND-2225 CB OPEN	0	2294	.	.
09/12/11 09:56	SW 18175 OPEN YUKON SWITCHING	0	.	.	.
09/12/11 09:57	SECTIONALIZER 40225 CLOSE YUC ON SWITCHING	1774	520	2	4588
09/12/11 10:00	NOTIFIED ASO FOR 2 T-MEN	0	.	.	.
09/12/11 10:56	SWITCH 3319 OPEN	0	.	.	.
09/12/11 11:00	GRAND ISLAND-2225 CB CLOSED NG	0	.	.	.
09/12/11 11:03	FIELD REPORTS POSSIBLE WIRED DOWN WILL CHK IT OUT	0	.	.	.
09/12/11 11:30	SWITCH 7871 CLOSE	408	112	95	52948
09/12/11 12:00	FOX RPTD WIRED DOWN BET 40799 AND COMBOS 6839/4187 RD Redacted	0	.	.	.
09/12/11 12:18	SWITCH 40799 OPEN ON DEAD LINE TAGGED MOL	0	.	.	.
09/12/11 12:21	GRAND ISLAND-2225 CB CLOSE	106	6	146	58660
09/12/11 13:52	SWITCH 40799 CLOSE	6	0	237	59206

ODT Remarks

Comment	Login	Date
note crew was standing by for damage to be found 2 tmen and a crew Redacted waiting for final word on where the wire is down on gr island rd	SLCC	09/12/2011 12:18
[OIS#405518 per DO need 2 tmen	LLR7	09/12/2011 09:59