

From: Cherry, Brian K
Sent: 9/21/2011 3:22:40 PM
To: pac@cpuc.ca.gov (pac@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: SF Gas Dig-In

FYI

Also - you were going to call Nick and chat about his concerns over the auditor ?

-----Original Message-----

From: Stavropoulos, Nickolas
Sent: Wednesday, September 21, 2011 3:22 PM
To: Cherry, Brian K
Cc: Yura, Jane
Subject: FW: SF Gas Dig-In

-----Original Message-----

From: [Redacted]
Sent: Wednesday, September 21, 2011 3:03 PM
To: BAR GAS_Update
Subject: Re: SF Gas Dig-In

Update - the saw cut damaged main is a 10" steel high pressure main. SFFD is on site and has evacuated one bld - [Redacted] so far. Gas Valve crews currently shutting down 9 emergency valves. We will interrupting 27 commercial services. Actual customer count is being counted. Valve crews trying to get through heavy traffic. More to come.

[Redacted]

----- Original Message -----

From: [Redacted]
Sent: Wednesday, September 21, 2011 02:22 PM
To: BAR GAS_Update
Subject: SF Gas Dig-In

At approximately 2:15, a contractor saw cut through a gas main in the intersection of Post & Mason. SFFD is just arriving on site. Valve crews in route. This will be a large shut down as we have a 10" steel main involved. More to follow.

[Redacted]