Circuit	062462225, Redacted 2225	District	Solano			
Туре	Unplanned	Customer Minutes	Sustained 55658 Momentary 3548			
Customers	Reda 520 Redac 1774 Initial 2294	Weather	Rain,Lightning,32-90 F			
Active	NO	Fault Type	Line to Ground			
Interval	Sustained	Action Required	No			
EquipID	OCB	Construction Type	OH			
Equipment Type	Circuit Breaker	OIS Outage#	405519			
Equipment Condition	Conductor, Overhead, On Ground	Targets	A B GRD T SET A RLY			
Crew Notified Time	09/12/11 10:05	Supervisor Notified	VACAVILLE CLERK Redacted			
Equipment Address	Redacted					
Fault Location	Redacted RD					
Previous Switching						
Details						
Action Description						
Cause	Equipment Failure/Involved, Other	No Access Reason				
Multi Damage Location	No	# of Operations	3			
Counter Read	69	Created By	Redact			
Outage Level	Distribution Circuit	Last Updated By	ed			
FNL	09/12/11 09:55	Reviewed By				
End Date	09/12/11 13:52	Reviewed By Date				
Actions						

Date	Description	Customers Restored	Customers Out	Minutes Out	Customer Minutes
09/12/11 09:55	Redacted -2225 CB OPEN	0	2294		
09/12/11 09:56	SW 18175 OPEN YUKON SWICTHING	0			
09/12/11 09:57	SECTIONALIZER 40225 CLOSE VUCON SWITCHING	1774	520	2	4588
09/12/11 10:00	NOTIFIED ASO FOR 2 T-MEN	0			
09/12/11 10:56	SWITCH 3319 OPEN	0			
09/12/11 11:00	Redacted 2225 CB CLOSED NG	0			
09/12/11 11:03	FIELD REPORTS POSSIBLE WIRE DOWN WILL CHK IT OUT	0			
09/12/11 11:30	SWITCH 7871 CLOSE	408	112	95	52948
09/12/11 12:00	FOX RPTD WIRE DOWN BET 40799 AND COMBOS 6839/4187 14757 Redacted	0			
09/12/11 12:18	SWITCH 40799 OPEN ON DEAD LINE TAGGED MOL	0			
09/12/11 12:21	Redacted -2225 CB CLOSE	106	6	146	58660
09/12/11 13:52	SWITCH 40799 CLOSE	6	0	237	59206

ODT Remarks

Comment	Logi	n Date]
note crew was standing by for damage to be found 2 tmen and a crew. delbono waiting for final word on where the wire is down on Reda	a Red	09/12/2011 12:18	12
[OIS#405518 per DOneed 2 tmen	lact	09/12/2011 09:59	