

Circuit 062462225, [Redacted] 2225
Type Unplanned
Customers [Reda] 520 [Reda] 1774 Initial 2294
Active NO
Interval Sustained
EquipID OCB
Equipment Type Circuit Breaker
Equipment Condition Conductor, Overhead, On Ground
Crew Notified Time 09/12/11 10:05
Equipment Address [Redacted]
Fault Location [Redacted] RD
Previous Switching Details
Action Description
Cause Equipment Failure/Involved, Other
Multi Damage Location No
Counter Read 69
Outage Level Distribution Circuit
FNL 09/12/11 09:55
End Date 09/12/11 13:52

District Solano
Customer Minutes Sustained 55658 Momentary 3548 C
Weather Rain,Lightning,32-90 F
Fault Type Line to Ground
Action Required No
Construction Type OH
OIS Outage# 405519
Targets A B GRD T SET A RLY
Supervisor Notified VACAVILLE CLERK [Redacted]

No Access Reason
of Operations 3
Created By [Redacted]
Last Updated By [Redacted]
Reviewed By
Reviewed By Date

Actions

| Date | Description | Customers Restored | Customers Out | Minutes Out | Customer Minutes |
|----------------|--|--------------------|---------------|-------------|------------------|
| 09/12/11 09:55 | [Redacted]-2225 CB OPEN | 0 | 2294 | . | . |
| 09/12/11 09:56 | SW 18175 OPEN YUKON SWITCHING | 0 | . | . | . |
| 09/12/11 09:57 | SECTIONALIZER 40225 CLOSE YUC ON SWITCHING | 1774 | 520 | 2 | 4588 |
| 09/12/11 10:00 | NOTIFIED ASO FOR 2 T-MEN | 0 | . | . | . |
| 09/12/11 10:56 | SWITCH 3319 OPEN | 0 | . | . | . |
| 09/12/11 11:00 | [Redacted]-2225 CB CLOSED NG | 0 | . | . | . |
| 09/12/11 11:03 | FIELD REPORTS POSSIBLE WIRED DOWN WILL CHK IT OUT | 0 | . | . | . |
| 09/12/11 11:30 | SWITCH 7871 CLOSE | 408 | 112 | 95 | 52948 |
| 09/12/11 12:00 | FOX RPTD WIRED DOWN BET 40799 AND COMBOS 6839/4187 [Redacted] RD | 0 | . | . | . |
| 09/12/11 12:18 | SWITCH 40799 OPEN ON DEAD LINE TAGGED MOL | 0 | . | . | . |
| 09/12/11 12:21 | [Redacted]-2225 CB CLOSE | 106 | 6 | 146 | 58660 |
| 09/12/11 13:52 | SWITCH 40799 CLOSE | 6 | 0 | 237 | 59206 |

ODT Remarks

| Comment | Login | Date |
|--|----------|------------------|
| note crew was standing by for damage to be found 2 tmen and a crew. delbono waiting for final word on where the wire is down on [Redacted] | Redacted | 09/12/2011 12:18 |
| [OIS#405518 per DO need 2 tmen | Redacted | 09/12/2011 09:59 |