

Circuit 062462225, [Redacted] 2225
Type Unplanned
Customers [Redacted] 20 [Redacted] 1774 Initial 2294
Active NO
Interval Sustained
EquipID OCB
Equipment Type Circuit Breaker
Equipment Condition Conductor, Overhead, On Ground
Crew Notified Time 09/12/11 10:05
Equipment Address [Redacted]
Fault Location [Redacted]
Previous Switching Details
Action Description
Cause Equipment Failure/Involved, Other
Multi Damage Location No
Counter Read 69
Outage Level Distribution Circuit
FNL 09/12/11 09:55
End Date 09/12/11 13:52

District Solano
Customer Minutes Sustained 55658 Momentary 3548 C
Weather Rain,Lightning,32-90 F
Fault Type Line to Ground
Action Required No
Construction Type OH
OIS Outage# 405519
Targets A B GRD T SET A RLY
Supervisor Notified VACAVILLE CLERK [Redacted]

No Access Reason
of Operations 3
Created By [Redacted]
Last Updated By [Redacted]
Reviewed By
Reviewed By Date

Actions

Date	Description	Customers Restored	Customers Out	Minutes Out	Customer Minutes
09/12/11 09:55	[Redacted] 2225 CB OPEN	0	2294	.	.
09/12/11 09:56	SW 18175 OPEN YUKON SWITCHING	0	.	.	.
09/12/11 09:57	SECTIONALIZER 40225 CLOSE YUC ON SWITCHING	1774	520	2	4588
09/12/11 10:00	NOTIFIED ASO FOR 2 T-MEN	0	.	.	.
09/12/11 10:56	SWITCH 3319 OPEN	0	.	.	.
09/12/11 11:00	[Redacted] 2225 CB CLOSED NG	0	.	.	.
09/12/11 11:03	FIELD REPORTS POSSIBLE WIRED DOWN WILL CHK IT OUT	0	.	.	.
09/12/11 11:30	SWITCH 7871 CLOSE	408	112	95	52948
09/12/11 12:00	FOX RPTD WIRED DOWN BET 40799 AND COMBOS 6839/4187 [Redacted]	0	.	.	.
09/12/11 12:18	SWITCH 40799 OPEN ON DEAD LINE TAGGED MOL	0	.	.	.
09/12/11 12:21	[Redacted] 2225 CB CLOSE	106	6	146	58660
09/12/11 13:52	SWITCH 40799 CLOSE	6	0	237	59206

ODT Remarks

Comment	Login	Date
note crew was standing by for damage to be found 2 tmen and a crew. delbono waiting for final word on where the wire is down on [Redacted]	[Redacted]	09/12/2011 12:18
[OIS#405518 per DO need 2 tmen	[Redacted]	09/12/2011 09:59