

From: Dowdell, Jennifer
Sent: 10/20/2011 3:30:42 PM
To: 'Shori, Sunil' (sunil.shori@cpuc.ca.gov); 'jmh@cpuc.ca.gov' (jmh@cpuc.ca.gov);
'mlc@cpuc.ca.gov' (mlc@cpuc.ca.gov)
Cc: Horner, Trina (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TNHC);
Ramaiya, Shilpa R (/o=PG&E/ou=Corporate/cn=Recipients/cn=SRRd)
Bcc:
Subject: Incident in Pleasanton

Michelle, Julie and Sunil,

Just FYI. There was a third-party dig in in Pleasanton today. No ignition. No injuries. Traffic rerouted. Background is below.

Jennifer

Background

At 1115 hours today October 20, Mozingo Construction dug in to a 4 inch plastic gas main allowing gas to escape. There was no ignition.

At 1120 hours, the contractor notified a nearby PG&E Electric Crew. Company gas personnel arrived at 1135 hours. The flow of gas was stopped at 1305 hours. Gas personnel are currently making repairs. The police and fire departments were present. Traffic was rerouted as a precaution.

There were no injuries or fatalities as a result of this incident. Personnel on the scene are currently determining how many customers are out. USA was notified and the line was properly marked although the contractor disputes this.

This incident was reported to the CPUC at 1350 hours due to presence of media and media inquires. Bay Area News Group and KGO TV (7) were present at the scene. Other media inquires were received from CBS Radio, KRON 4, and KTVU.