

PACIFIC GAS AND ELECTRIC COMPANY
Data Response

PG&E Data Request No.:	CPUC_200-05		
PG&E File Name:	DR_CPUC_200-Q05		
Request Date:	October 4, 2011	Requester DR No.:	
Date Sent:	October 7, 2011	Requesting Party:	CPUC (CPSD)
		Requester:	Clayton Tang

QUESTION 5

Please provide us with information about the number of feet or miles tested, sampled, replaced, etc., for the money spent in 2009, 2010, and 2011, as well as forecasted for 2012-2013?

ANSWER 5

The DIMP Aldyl-A program is focused on ensuring that all vintages of Aldyl-A have been sampled and tested. Accordingly, the actual footage that gets tested, sampled and/or replaced is not particularly relevant. That said, under the Aldyl-A program, for testing purposes in 2009 and 2010, PG&E removed approximately 500 feet of Aldyl-A from the Fresno, Kettleman, Oakley, and Antioch areas. In 2011, PG&E is planning to sample and test approximately 100 feet of Aldyl-A pipe in Fresno.

As described above, PG&E has not yet planned its 2012 and 2013 Aldyl-A work.

The footage replacement described above does not include the replacements described in response to question 1 above or any replacements performed in the normal course of business.