

From: Cherry, Brian K
Sent: 10/10/2011 11:36:34 AM
To: pac@cpuc.ca.gov (pac@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: Gas Incident at Big Horn Blvd, Elk Grove

fyi

From: [Redacted]
Sent: Monday, October 10, 2011 11:31 AM
To: UO EP Gas Incident Notify
Cc: [Redacted]; [Redacted]
Subject: Gas Incident at Big Horn Blvd, Elk Grove

At 0745 hrs on 10-10-11 a [Redacted] a 3rd party contractor hit a 4-inch plastic main operating at 57 psig with a back hoe. USA was notified and the pipe was properly marked.

PG&E was notified of this incident by the contractor at 0753 hrs. A PG&E crew arrived on scene at 0844 hrs; traffic was rerouted and the area blocked off.

This incident was determined to be reportable due to media on scene at 0844 hrs (Fox 40 News). The CPUC was notified of this incident today at 1032 hrs. There were no fatalities and no injuries as a result of this incident. Damage to company property, including loss of gas is estimated at less than \$50,000.

The flow of gas is expected to be stopped at Noon today. No customers are out of service as a result of this incident.

Please contact [Redacted] if you have any questions or require any additional information.

[Redacted]

Principal Gas Engineer

Gas Design and Planning