

From: Cherry, Brian K  
Sent: 10/11/2011 1:10:13 PM  
To: 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fw: Excelsior District Outage

T and C to the rescue. No T and A.

**From:** Dashner, Andrew M  
**Sent:** Tuesday, October 11, 2011 01:04 PM  
**To:** SF\_Update  
**Subject:** FW: Excelsior District Outage

Excelsior Update: Upon arrival, T-men found a failed tap on an overhead switch. Operations is in the process of isolating the switch and is concurrently restoring the 12KV feed to Silver Sub which will restore the majority of the customers. We will have one overhead transformer in the isolated section that will remain out until the overhead tap is repaired. An M&C crew is enroute to expedite repairs.

Andy

---

**From:** Dashner, Andrew M  
**Sent:** Tuesday, October 11, 2011 12:41 PM  
**To:** SF\_Update  
**Subject:** Excelsior District Outage

All,

We have a large outage affecting approximately 2585 customers on both the Silver 401 and H-1106 circuits in the Excelsior and Visitacion Valley districts. At this time we suspect that both outages are related. Multiple T-men and C-men are enroute. We also have a preliminary report of a failed overhead transformer at the 100 block of Goettingen. More to come.

Andy