

COMMISSIONERS  
 FREDERICK B. HOLOBOFF, PRESIDENT  
 PETER E. MITCHELL  
 GEORGE G. GROVER  
 WILLIAM M. BENNETT  
 A. W. GATOV



Public Utilities Commission

STATE OF CALIFORNIA

July 22, 1965

LHS	COAST VALLEYS DIVISION			OOB
SLC	REPLY	FILE	CIRCULATE	EMH
EMK	JUL 26 1965			WPT
DSA				RKM
EEH				LCS
ECH	ONLY COPY			RAB
CHB	COPY TO			HJD
RRJ				EAG

FILE NO. G.O. 112-A/5-65 CALIFORNIA STATE BUILDING  
 SAN FRANCISCO, CALIF. 94102

ADDRESS ALL COMMUNICATIONS  
 TO THE COMMISSION

Pacific Gas and Electric Company  
 245 Market Street  
 San Francisco, California 94106

Attention: Mr. John C. Morrissey  
 Attorney

Gentlemen:

This will acknowledge receipt of your letter dated June 29, 1965, forwarding for filing a proposed 8 mile, 16-inch pipeline extension from feeder Main 301 near Castroville in order to boost the gas capacity of Monterey No. 2 main in Fort Ord. The report indicates that the installation will take place in areas of Class 3 location and Type C construction will be employed throughout the project. Since the pipe material used is salvage and reconditioned pipes from Main No. 100 originally installed in 1929, with 33,000 minimum yield and (80%) joint efficiency, the maximum allowable operating pressure under Section 107 of General Order No. 112-A will be 412 psig.

The report submitted in accordance with the requirements of Chapter IV, Section 401.2 of General Order No. 112-A has been reviewed and is acceptable for filing.

Very truly yours,

PUBLIC UTILITIES COMMISSION  
 STATE OF CALIFORNIA

By *William W. Dunlop*  
 William W. Dunlop, Secretary

7-23-65

cc: EHFisher RDSmith LHSmith EFSibley MHChandler  
 ATSchmidt