



Pacific Gas and Electric Company
Gas Pipeline Facilities Strength Test Pressure Report
 (For Pipeline Facilities Designed to Operate over 100 PSIG)



62-4921 (Rev. 2/04)
 California Gas Transmission
 (Use in Accordance with Gas Standard A-34 and GC 112-D)

Sheet 1 of 3

PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)									
Feeder Main Number, Line Number, or Station Name L-101			Area 1		Division/District Peninsula		Job Number 41474062-T2/3		Date Job Authorized 5/27/11
Description of Job - Include Reference Drawing Numbers, and Pipeline Mileposts STPR 41474062T2 - Hydrostatically test 36" tie-in piping, hydrostatic test piping and existing 34" and 36" L-101. Existing material listed; i.e. pipe, elbows, sleeves, are from the "Material of Record". (refer to DWG 414740062-T2/3, Sheet 7). T-2 - Hydrotest L-101 from MP 0.62 to MP 3.08, in San Jose and Santa Clara. Test 2 (Location B to C on Dwg. 414740062-T2/T3))									
Location Class 3		Design Factor (F) .5		MAOP to be Established for this Piping by this Test 400 PSIG			Future Design Pressure 400 PSIG		
STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)		Max. Elevation 17 Ft.		Static Head Calculation		For Water 0.433 X Elev. Diff. = 8 PSIG		Other (Specify) X Elev. Diff. = 8 PSIG	
Min. Elevation 0 Ft.		Elev. Diff. 17 Ft.		Pipe Specification		Pipe Spec. and Footage Verified In Field		% of SMYS	
O.D.		W.T.		API or ASTM Grade Long Seam (ERW, DSAW, Seamless, Etc.)		Footage to Be Tested		At MAOP	
At Min. Test Press.		At Max. Test Press.		Pressure to Give 90% SMYS					
36.00	0.500	API 5L, X-65, DSAW (Item#50)		75'	135' - 2"	22.15	37.66	43.20	1625
10.75	0.365	API 5L, GrB, SMLS (Item #53)		8'	Tested with T-3	16.83	28.61	32.82	2139
3.500	0.216	API 5L, GrB, SMLS (Item #54)		8'	Tested with T-3	9.26	15.74	18.06	3888
2.375	0.154	API 5L, GrB, SMLS (Item #55)		4'	Tested with T-3	8.81	14.98	17.18	4085
36.00	0.350	API 5L, X-52, DSAW (Item#1)		11,065'	M.O.R.	39.56	67.25	77.14	910 MAX
36.00	0.469	API 5L, X-52, DSAW (Item#3)		310'	M.O.R.	29.52	50.19	57.57	1219
Minimum Test Pressure @ Max. Elevation 680 PSIG				Test Fluid To Be Used WATER		MINIMUM TEST DURATION - UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34) 8 HOURS		Maximum Test Pressure @ Min. Elevation 780 PSIG	
Prepared By: Redacted		Date: 05/27/11		For Information or Changes, Call: Redacted		Approved By: Redacted		Date: 9/2/11	
TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)						Note: Minimum test pressure and duration are not to be changed without written approval.			
Time and Date Test Pressure Reached 1045 hrs 6-5-11		Elevation at Test Point 8.0 FT		Min. Required Test Press. At Test Point (1) 684 PSIG		Max. Allowable Test Press at Test Point (4) 777 PSIG			
Time and Date Test Ended 2000 hrs 6-5/11		Max. Elevation in Test Section 17 FT		Min. Indicated Test Pressure (2) 710 PSIG		Max. Indicated Test Pressure (5) 752 PSIG		910 PSIG OK	
Actual Duration of Test 9 hrs. 15 min		Min. Elevation in Test Section 0 FT		Min. Test Pressure at Max. Elevation (3) 706 PSIG		Max. Test Pressure at Min. Elevation (6) 756 PSIG			
Test Fluid Used Water				Pipe Specification and Footage Verified (See Part I) Above					
Make, Range, and Serial No. of Pressure Recording Gauge CPL 1703 0-1000 PSI			Date Last Calibrated 5-2-11		Make, Range, and Serial No. of Dead Weight Tester (See Note 7) Ametek s/n 2845 0.3500 PSI			Date Last Calibrated 11-29-10	
Test Sign: Redacted		Date: 8-11-11		Approved By: Redacted		Date: 8-4-11			
PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.									
NOTES: (1) Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I. (2) Use lowest pressure on test gauge at any time during test. (3) Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure. (4) Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I. (5) Highest pressure on test gauge at any time during test. (6) Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure. (7) A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.					DISTRIBUTION JOB FILE (AT SPONSORING ORGANIZATION) GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT PROJECT MANAGER/PROJECT ENGINEER TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB) RECORDS SECTION (WC), GSM&TS REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING				

① originally signed on 6-8-11 ② ORIGINAL signed 6-5-11
 ③ original signed 5/29/11



Gas Pipeline Facilities Strength Test Pressure Report
(For Pipeline Facilities Designed to Operate over 100 PSIG)



California Gas Transmission
(Use in Accordance With Gas Standard A-34 and GO 112-D)

Sheet 2 of 3

PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)

Feeder Main Number, Line Number, or Station Name L-101	Area 1	Division/District Peninsula	Job Number 41474062-T2/3	Date Job Authorized 5/27/11
--	------------------	---------------------------------------	------------------------------------	---------------------------------------

Description of Job -- Include Reference Drawing Numbers, and Pipeline Mileposts
STPR 41474062T2 - Hydrostatically test 36" tie-in piping, hydrostatic test piping and existing 34" and 36" L-101. Existing material listed; i.e. pipe, elbows, sleeves, are from the "Material of Record". (refer to DWG 414740062-T2/3, Sheet 7).

T-2 - Hydrotest L-101 from MP 0.62 to MP 3.08, in San Jose and Santa Clara. Test 2 (Location B to C on Dwg. 414740062-T2/T3))

Location Class 3	Design Factor (F) .5	MAOP to be Established for this Piping by this Test 400 PSIG	Future Design Pressure 400 PSIG
----------------------------	--------------------------------	--	---

STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)	Max. Elevation 17 Ft.	Static Head Calculation	
	Min. Elevation 0 Ft.	For Water	0.433 X Elev. Diff. = 8 PSIG
	Elev. Diff. 17 Ft.	Other (Specify)	X Elev. Diff. = PSIG

Size		Pipe Specification API or ASTM Grade Long Seam (ERW, DSAW, Seamless, Etc.)	Footage to Be Tested	Pipe Spec. and Footage Verified In Field	% of SMYS			Pressure to Give 90% SMYS
O.D.	W.T.				At MAOP	At Min. Test Press.	At Max. Test Press.	
34.00	0.500	API 5L, X-52, DSAW (Item #6)	2'	M.O.R.	26.15	44.46	51.00	1377
34.00	0.375	API 5L, X-46, DSAW (Item#10)	225'	M.O.R.	39.42	67.01	76.87	913
36.00	0.422	API 5L, X-52, DSAW (Item #4)	520'	M.O.R.	32.81	55.78	63.98	1097
34.00	0.344	API 5L, X-52, DSAW (Item #7)	324'	M.O.R.	38.01	64.62	74.13	947
34.00	0.437	API 5L, X-52, DSAW (Item #8)	19'	M.O.R.	29.89	50.81	58.29	1205
36.00	0.375	Elbow, Y-52 (Item #14)	7 Ea.	M.O.R.	36.92	62.77	72.00	975
36.00	UNK	Elbow, Unknown Grade (Item#15)	3 Ea.	M.O.R.	-	-	-	-
36.00	0.625	Elbow, Y-52 (Item#20)	4 Ea.	M.O.R.	22.15	37.66	43.20	1625
36.00	UNK	Elbow, Unknown Grade (Item#30)	1 Ea.	M.O.R.	-	-	-	-
		Elbow SLEEVE 3P						

Minimum Test Pressure @ Max. Elevation 680 PSIG	Test Fluid To Be Used WATER	MINIMUM TEST DURATION - UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34)	8 HOURS
Maximum Test Pressure @ Min. Elevation 780 PSIG			

Prepared By: **Mark A. Cabral** Date: **05/27/11** For Information or Changes, Call: **Redacted** Approved By: *[Signature]* Date: **9/7/11**

PART II - TEST DATA (TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)

Note: Minimum test pressure and duration are not to be changed without written approval.

Time and Date Test Pressure Reached 1045 hrs 6-5-11	Elevation at Test Point 8 FT	Min. Required Test Press. At Test Point (1) 684 PSIG	Max. Allowable Test Press at Test Point (4) 777 PSIG
Time and Date Test Ended 2000 hrs. 6-5-11	Max. Elevation in Test Section 17 FT	Min. Indicated Test Pressure (2) 710 PSIG	Max. Indicated Test Pressure (5) 752 PSIG
Actual Duration of Test 9 hrs. 15 min	Min. Elevation in Test Section 0 FT	Min. Test Pressure at Max. Elevation (3) 706 PSIG	Max. Test Pressure at Min. Elevation (6) 756 PSIG

Test Fluid Used: **Water** Pipe Specification and Footage Verified (See Part I): **Above**

Make, Range, and Serial No. of Pressure Recording Gauge CPL 1703 0-1000 PSI	Date Last Calibrated 5-2-11	Make, Range, and Serial No. of Dead Weight Tester (See Note 7) Ametek s/n 2845 0-3500 PSI	Date Last Calibrated 11-29-10
---	---------------------------------------	---	---

Test Supervised By: *[Signature]* Date: **8-11-11** Approved By: *[Signature]* Date: **8-4-11**

PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET

SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.

NOTES:

- Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I.
- Use lowest pressure on test gauge at any time during test.
- Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure.
- Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I.
- Highest pressure on test gauge at any time during test.
- Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure.
- A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.

DISTRIBUTION

- JOB FILE (AT SPONSORING ORGANIZATION)
- GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT
- PROJECT MANAGER/PROJECT ENGINEER
- TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY
- CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB)
- RECORDS SECTION (WC), GSM&TS
- REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING

① originally signed on 6-8-11 ② original signed 6-5-11 ③ original signed 5/28/11



Gas Pipeline Facilities Strength Test Pressure Report
(For Pipeline Facilities Designed to Operate over 100 PSIG)



California Gas Transmission
(Use In Accordance with Gas Standard A-34 and GO 112-D)

Sheet 3 of 3

PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)

Feeder Main Number, Line Number, or Station Name L-101	Area 1	Division/District Peninsula	Job Number 41474062-T2/3	Date Job Authorized 5/27/11
--	------------------	---------------------------------------	------------------------------------	---------------------------------------

Description of Job -- Include Reference Drawing Numbers, and Pipeline Mileposts
STPR 41474062T2 - Hydrostatically test 36" tie-in piping, hydrostatic test piping and existing 34" and 36" L-101. Existing material listed; i.e. pipe, elbows, sleeves, are from the "Material of Record". (refer to DWG 414740062-T2/3, Sheet 7).

T-2 - Hydrotest L-101 from MP 0.62 to MP 3.08, in San Jose and Santa Clara. Test 2 (Location B to C on Dwg. 414740062-T2/T3)

Location Class 3	Design Factor (F) .5	MAOP to be Established for this Piping by this Test 400 PSIG	Future Design Pressure 400 PSIG
----------------------------	--------------------------------	--	---

STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)	Max. Elevation <u>17</u> Ft.	Min. Elevation <u>0</u> Ft.	Elev. Diff. <u>17</u> Ft.	Static Head Calculation	For Water 0.433 X Elev. Diff. = <u>8</u> PSIG	Other (Specify)	X Elev. Diff. = <u> </u> PSIG
--	------------------------------	-----------------------------	---------------------------	-------------------------	---	-----------------	--

Size		Pipe Specification		Footage to Be Tested	Pipe Spec. and Footage Verified In Field	% of SMYS			Pressure to Give 90% SMYS
O.D.	W.T.	API or ASTM Grade	Long Seam (ERW, DSAW, Seamless, Etc.)			At MAOP	At Min. Test Press.	At Max. Test Press.	
36.00	0.375	Sleeve, Y-60, GrE	(Item#29)	1Ea.	M.O.R.	32.00	54.40	62.40	1125
34.00	0.406	Elbow, Unknown Grade	(Item#17)	1Ea.	M.O.R.	-	-	-	-
34.00	0.406	Elbow, Unknown Grade	(Item#19)	2Ea.	M.O.R.	-	-	-	-
34.00	0.500	Elbow, Unknown Grade	(Item#18)	1Ea.	M.O.R.	-	-	-	-
34.00	0.375	Elbow, Y-52	(Item#16)	1Ea.	M.O.R.	34.87	59.28	68.00	1032
34.00	0.375	Elbow, Unknown Grade	(Item#24)	1Ea.	M.O.R.	/	/	/	/

Minimum Test Pressure @ Max. Elevation	680 PSIG	Test Fluid To Be Used	WATER	MINIMUM TEST DURATION	8 HOURS
Maximum Test Pressure @ Min. Elevation	780 PSIG			- UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34) (3)	

Prepared By: Mark A. Cabral	Date: 05/27/11	For Information or Changes Call: Redacted	Approved By: <i>[Signature]</i>	Date: 9/6/11
---------------------------------------	--------------------------	---	------------------------------------	------------------------

PART II - TEST DATA (TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)

Note: Minimum test pressure and duration are not to be changed without written approval.

Time and Date Test Pressure Reached	1045 hrs. 6-5-11	Elevation at Test Point	8 FT	Min. Required Test Press. At Test Point (1)	684 PSIG	Max. Allowable Test Press at Test Point (4)	777 PSIG
Time and Date Test Ended	2000 hrs 6-5-11	Max. Elevation in Test Section	17 FT	Min. Indicated Test Pressure (2)	710 PSIG	Max. Indicated Test Pressure (5)	752 PSIG
Actual Duration of Test	9 hrs. 15min.	Min. Elevation in Test Section	0 FT	Min. Test Pressure at Max. Elevation (3)	706 PSIG	Max. Test Pressure at Min. Elevation (6)	756 PSIG

Test Fluid Used Water	Pipe Specification and Footage Verified (See Part I) Above		
Make, Range, and Serial No. of Pressure Recording Gauge CPL 0-1000 PSI	Date Last Calibrated 5-2-11	Make, Range, and Serial No. of Dead Weight Tester (See Note 7) Ametek s/n 2845 0-3500 PSI	Date Last Calibrated 11-29-10

Test Supervised By: <i>[Signature]</i> (2)	Date: 8-11-11	Approved By: <i>[Signature]</i> 8-4-11	Date:
--	-------------------------	--	----------------------------

PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET
SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.

- NOTES:**
- Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I.
 - Use lowest pressure on test gauge at any time during test.
 - Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure.
 - Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I.
 - Highest pressure on test gauge at any time during test.
 - Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure.
 - A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.

DISTRIBUTION
JOB FILE (AT SPONSORING ORGANIZATION) **(3) Original Signed**
GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT **on 5/28/11**
PROJECT MANAGER/PROJECT ENGINEER
TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY
CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB)
RECORDS SECTION (WC), GSM&TS
REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING

Drawings signed on 6-8-11 (2) ORIGINAL SIGNED 6-5-11



Pacific Gas and Electric Company
Gas Pipeline Facilities Strength Test Pressure Report
 (For Pipeline Facilities Designed to Operate over 100 PSIG)



62-4921 (Rev. 2/04)
 California Gas Transmission
 (Use in Accordance with Gas Standard A-34 and GO 112-D)

Sheet 1 of 2

PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)

Feeder Main Number, Line Number, or Station Name: L-101	Area: 1	Division/District: Peninsula	Job Number: 41474062-T2/3	Date Job Authorized: 5/27/11
---	-------------------	--	-------------------------------------	--

Description of Job - Include Reference Drawing Numbers, and Pipeline Mileposts:
STPR #41474062T3 - Hydrostatically test 36" tie-in piping, hydrostatic test piping and existing 30", 34" and 36" L-101. Existing material listed; ie. pipe, elbows, sleeves, are from the "Material of Record". (refer to DWG 414740062-T2/3, Sheet 7).

T-3 - Hydrotest L-101 from MP 3.08 to MP 4.66, in Santa Clara. (Location B to A on Dwg. 414740062-T2/T3)

Location Class: 3	Design Factor (F): .5	MAOP to be Established for this Piping by this Test: 400 PSIG	Future Design Pressure: 400 PSIG
-----------------------------	---------------------------------	---	--

STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)	Max. Elevation:	8 Ft.	Static Head Calculation For Water: 0.433 X Elev. Diff. = 4.0 PSIG Other (Specify): X Elev. Diff. = PSIG
	Min. Elevation:	0 Ft.	
	Elev. Diff.:	8 Ft.	

Pipe Specification		Footage to Be Tested	Pipe Spec. and Footage Verified In Field	% of SMYS			Pressure to Give 90% SMYS	
Size O.D.	W.T.			API or ASTM Grade Long Seam (ERW, DSAW, Seamless, Etc.)	At MAOP	At Min. Test Press.		At Max. Test Press.
36.00	0.500	API 5L, X-65, DSAW (Item#50)	70 - 1 1/2"	70 - 1 1/2"	22.15	37.66	43.20	1625
30.00	0.500	API 5L, X-60, DSAW (Item #13)	1504.5'	1504.5'	20.00	34.00	39.00	1800
36.00	0.350	API 5L, X-52, DSAW (item #1)	6437'	6106.5'	39.56	67.25	77.14	910 MAX
36.00	0.4375	API 5L, X-52, DSAW (Item#2)	217'	217'	31.65	53.80	61.70	1138
34.00	0.562	API 5L, X-60, DSAW (Item#11)	6'	6'	20.17	34.28	39.32	1785
34.00	0.375	API 5L, X-46, DSAW (Item#10)	419'	419'	39.42	67.01	76.87	913
36.00	0.432	API 5L, X-60, DSAW (Item#5)	7.5'	7.5'	27.78	47.22	54.17	1296
34.00	0.4375	API 5L, X-52, DSAW (Item#8)	64'	64'	29.89	50.81	58.29	1205
10.75	0.365	API 5L, GrB, SMLS (Item #53)	10'	10'	16.83	28.61	32.82	2139
3.500	0.216	API 5L, GrB, SMLS (Item #54)	10'	10'	9.26	15.74	18.06	3888
21.375	0.154	API 5L, GrB, SMLS (Item #55)	32 18' 10"	10'	8.81	14.98	17.18	4085

Minimum Test Pressure @ Max. Elevation:	680 PSIG	Test Fluid To Be Used: WATER	MINIMUM TEST DURATION - UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34)	8 HOURS
Maximum Test Pressure @ Min. Elevation:	780 PSIG			

Prepared By: **Mark Cabral** Date: **05/27/11** For Information or Changes, Call: **Redacted** Approved By: *[Signature]* Date: **9/7/11** (3)

PART II - TEST DATA (TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)

Time and Date Test Pressure Reached:	6-7-11 751 PSI 1245 am	Elevation at Test Point:	8 FT	Min. Required Test Press. At Test Point (1):	680 PSIG	Max. Allowable Test Press at Test Point (4):	777 PSIG
Time and Date Test Ended:	6-7-11 702 PSI 900 am	Max. Elevation in Test Section:	8 FT	Min. Indicated Test Pressure (2):	702 PSIG	Max. Indicated Test Pressure (5):	751 PSIG
Actual Duration of Test:	8 hrs. 15 min.	Min. Elevation in Test Section:	0 FT	Min. Test Pressure at Max. Elevation (3):	702 PSIG	Max. Test Pressure at Min. Elevation (6):	754 PSIG

Test Fluid Used: **Water** Pipe Specification and Footage Verified (See Part I): **Above 35**

Make, Range, and Serial No. of Pressure Recording Gauge: CPL 1703 0-1000 PSI	Date Last Calibrated: 5-2-11	Make, Range, and Serial No. of Dead Weight Tester (See Note 7): Ametek 0-3500 PSI 2845	Date Last Calibrated: 11-29-10
--	--	--	--

Test Supervised By: *[Signature]* (2) Date: **8-11-11** Approved By: *[Signature]* Date: **8-4-11** (1)

PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET
 SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.

- NOTES:**
- Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I.
 - Use lowest pressure on test gauge at any time during test.
 - Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure.
 - Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I.
 - Highest pressure on test gauge at any time during test.
 - Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure.
 - A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.
- DISTRIBUTION**
 JOB FILE (AT SPONSORING ORGANIZATION)
 GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT
 PROJECT MANAGER/PROJECT ENGINEER
 TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY
 CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB)
 RECORDS SECTION (WC), GSM&TS
 REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING

[Handwritten notes] Original signed 6-8-11 (2) original signed 6-7-11



PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)											
Feeder Main Number, Line Number, or Station Name L-101			Area 1		Division/District Peninsula		Job Number 41474062-T2/3		Date Job Authorized 5/27/11		
Description of Job -- Include Reference Drawing Numbers, and Pipeline Mileposts STPR 41474062T3 - Hydrostatically test 36" tie-in piping, hydrostatic test piping and existing 30", 34" and 36" L-101. Existing material listed; ie. pipe, elbows, sleeves, are from the "Material of Record". (refer to DWG 414740062-T2/3, Sheet 7). T-3 - Hydrotest L-101 from MP 3.08 to MP 4.66, in Santa Clara. Test 3 (Location B to A on Dwg. 414740062-T2/T3)											
Location Class 3		Design Factor (F) .5		MAOP to be Established for this Piping by this Test 400 PSIG			Future Design Pressure 400 PSIG				
STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)		Max. Elevation 8 Ft.		Min. Elevation 0 Ft.		Elev. Diff. 8 Ft.		Static Head Calculation For Water 0.433 X Elev. Diff. = 4.0 PSIG		Other (Specify) X Elev. Diff. = PSIG	
Pipe Specification				Footage to Be Tested		Pipe Spec. and Footage Verified in Field		% of SMYS			Pressure to Give 90% SMYS
Size O.D. W.T.		API or ASTM Grade Long Seam (ERW, DSAW, Seamless, Etc.)						At MAOP	At Min. Test Press.	At Max. Test Press.	
36.00 0.375		Elbow, Y-52 (Item#14)		6 Ea.				36.92	62.77	72.00	975
30.00 0.500		Elbow, Y-60 (Item#22)		14 Ea.				20.00	34.00	39.00	1800
34.00 UNK		Sleeve, Unknown Grade (Item#31)		1 Ea.				-	-	-	-
36.00 0.375		Elbow, Unknown Grade (Item#24)		4 Ea.				-	-	-	-
36.00 UNK		Sleeve, Unknown Grade (Item#30)		2 Ea.				-	-	-	-
34.00 0.500		Elbow, Unknown Grade (Item#23)		1 Ea.				-	-	-	-
Minimum Test Pressure @ Max. Elevation 680 PSIG				Test Fluid To Be Used WATER		MINIMUM TEST DURATION - UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34)			8 HOURS		
Maximum Test Pressure @ Min. Elevation 780 PSIG				Prepared By: Mark Cabral		Date: 05/27/11		For Information or Changes, Call: Redacted		Approved By: <i>[Signature]</i> Date: 9/7/11	
PART II - TEST DATA (TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)						Note: Minimum test pressure and duration are not to be changed without written approval.					
Time and Date Test Pressure Reached		6-7-11 751 PSI 1245 am		Elevation at Test Point 8 FT		Min. Required Test Press. At Test Point (1) 680 PSIG		Max. Allowable Test Press at Test Point (4) 777 PSIG			
Time and Date Test Ended		6-7-11 702 PSI 900 am		Max. Elevation in Test Section 8 FT		Min. Indicated Test Pressure (2) 702 PSIG		Max. Indicated Test Pressure (5) 751 PSIG			
Actual Duration of Test		8 hrs. 15 min		Min. Elevation in Test Section 0 FT		Min. Test Pressure at Max. Elevation (3) 702 PSIG		Max. Test Pressure at Min. Elevation (6) 754 PSIG			
Test Fluid Used Water				Pipe Specification and Footage Verified (See Part I) Above							
Make, Range, and Serial No. of Pressure Recording Gauge CPL 1703 0-1000 PSI				Date Last Calibrated 5-2-11		Make, Range, and Serial No. of Dead Weight Tester (See Note 7) Armetek 0-3500 PSI 2845			Date Last Calibrated 11-29-10		
Test Supervised By: <i>[Signature]</i>				Date: 8-11-11		Approved By: <i>[Signature]</i>			Date: 8-4-11		
PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.											
NOTES:						DISTRIBUTION					
(1) Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I.						JOB FILE (AT SPONSORING ORGANIZATION)					
(2) Use lowest pressure on test gauge at any time during test.						GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT					
(3) Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure.						PROJECT MANAGER/PROJECT ENGINEER					
(4) Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I.						TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY					
(5) Highest pressure on test gauge at any time during test.						CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB)					
(6) Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure.						RECORDS SECTION (WC), GSM&TS					
(7) A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.						REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING					

*① originally signed on 6-8-11 ② original signed 6-7-11
 ③ original signed 5/29/11*