

From: Campbell, Ben (NRD)
Sent: 11/10/2011 12:22:52 PM
To: 'Shori, Sunil' (sunil.shori@cpuc.ca.gov)
Cc: Horner, Trina (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TNHC);
Ramaiya, Shilpa R (/o=PG&E/ou=Corporate/cn=Recipients/cn=SRRd); Halligan,
Julie (julie.halligan@cpuc.ca.gov); Dowdell, Jennifer
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=JKD5)
Bcc:
Subject: T-30 New Test and T-31 pictures

Hi Sunil:

We are re-testing T-30 in Palo Alto today and the pipe held pressure without leaking at our 75% hold point and at about 11:55 the spike test was completed at 759 psi. The pressure has been lowered to 710 psi for the remainder of the 8 hour test. The pipe is very unlikely to experience a rupture at this point, but another leak could possibly develop but this is also unlikely.

Here are some pictures of the gouges on Line 132 at the rupture point of T-31.

Ben Campbell
PG&E

<<...>> <<...>> <<...>> <<...>> <<...>>