

From: Horner, Trina
Sent: 11/10/2011 9:28:30 PM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7);
'paul.clanon@cpuc.ca.gov' (paul.clanon@cpuc.ca.gov); Doll, Laura
(/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=LRDD)
Cc:
Bcc:
Subject: Re: Fwd: Ruptured line on [Redacted]
Tell me.

From: Clanon, Paul [mailto:paul.clanon@cpuc.ca.gov]
Sent: Thursday, November 10, 2011 09:19 PM
To: Cherry, Brian K; Horner, Trina; Doll, Laura
Subject: Fwd: Ruptured line on [Redacted]

Sigh.

Begin forwarded message:

From: "Cooke, Michelle" <michelle.cooke@cpuc.ca.gov>
Date: November 10, 2011 9:04:13 PM PST
To: "Prosper, Terrie D." <terrie.prosper@cpuc.ca.gov>, "Clanon, Paul"
<paul.clanon@cpuc.ca.gov>
Subject: Re: Ruptured line on [Redacted]

PG&E crews were working at [Redacted] and pulled a 4 inch drip line
out of a 16 inch high pressure main. Gas is blowing, no ignition. 4 valves are
being closed. Channel 5 is on scene.

From: Prosper, Terrie D.
Sent: Thursday, November 10, 2011 09:01 PM
To: Cooke, Michelle; Clanon, Paul
Subject: Re: Ruptured line on [Redacted]

[Redacted] Maybe they're trying to do
themselves in...

From: Cooke, Michelle
Sent: Thursday, November 10, 2011 08:58 PM
To: Clanon, Paul; Prosper, Terrie D.
Subject: Fw: Ruptured line on [Redacted]

The crap never ends. Will let you know what I learn...

From: Robertson, Michael
Sent: Thursday, November 10, 2011 08:56 PM
To: Cooke, Michelle; Halligan, Julie; Shori, Sunil
Subject: RE: Ruptured line on [Redacted]

[Redacted] told me that PG&E will be reporting to us soon with the details.

From: Cooke, Michelle
Sent: Thursday, November 10, 2011 8:53 PM
To: Halligan, Julie; Shori, Sunil; Robertson, Michael
Subject: Re: Ruptured line on [Redacted]

Not yet

From: Halligan, Julie
Sent: Thursday, November 10, 2011 08:30 PM
To: Cooke, Michelle; Shori, Sunil; Robertson, Michael
Subject: Ruptured line on [Redacted]

Anyone hear anything about a gas line problem in SF?