

From: Cherry, Brian K
Sent: 11/25/2011 12:09:43 PM
To: 'mlc@cpuc.ca.gov' (mlc@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fw: FATALITY FROM CONTACT
FYI

From: Cherry, Brian K
Sent: Friday, November 25, 2011 12:09 PM
To: Williams, Geisha; Kiraly, Gregory; Lemler, Gregg
Cc: Pruett, Greg S.
Subject: Re: FATALITY FROM CONTACT

Thanks Geisha. When you hear more, please let me know and I can share it with the Commission.

From: Williams, Geisha
Sent: Friday, November 25, 2011 11:59 AM
To: Kiraly, Gregory; Lemler, Gregg
Cc: Cherry, Brian K; Pruett, Greg S.
Subject: Fw: FATALITY FROM CONTACT

Have appropriate notifications occurred?

Geisha

From: [Redacted]
Sent: Friday, November 25, 2011 07:46 AM
To: CC CES CE ES&S Outage Escalation
Cc: [Redacted]
Subject: FATALITY FROM CONTACT

FYI

Outage: 456244 @ 00:51, Region Northern, Shasta District : DESCHUTES 1101.
Device 1580. Cust: 360. @ 0246 HRS PARKER RPTS FATALITY FROM CONTACT, we
will provide more information as it becomes available.

[Redacted]

Account Manager

Pacific Gas and Electric Company
CES-Energy Solutions and Service

[Redacted]

Redacted



Please consider the environment before printing this e-mail.