

From: Clanon, Paul
Sent: 11/25/2011 1:13:09 PM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)
Cc: mlc@cpuc.ca.gov (mlc@cpuc.ca.gov)
Bcc:
Subject: Re: FATALITY FROM CONTACT
Shit.

On Nov 25, 2011, at 1:04 PM, "Cherry, Brian K" <BKC7@pge.com> wrote:

FYI

From: Williams, Geisha
Sent: Friday, November 25, 2011 12:43 PM
To: Cherry, Brian K
Subject: Re: FATALITY FROM CONTACT

Here's what the text I received said.

CPUC Elec Incident: 3rd Party Fatality. NV division, City of Oakrun. 3rd party vehicle hit pole & wire fell on vehicle. Preliminary rpt is driver exited vehicle contacting energized 12kV wire resulting in fatal injuries.

From: Cherry, Brian K
Sent: Friday, November 25, 2011 12:09 PM
To: Williams, Geisha; Kiraly, Gregory; Lemler, Gregg
Cc: Pruett, Greg S.
Subject: Re: FATALITY FROM CONTACT

Thanks Geisha. When you hear more, please let me know and I can share it with the Commission.

From: Williams, Geisha
Sent: Friday, November 25, 2011 11:59 AM
To: Kiraly, Gregory; Lemler, Gregg
Cc: Cherry, Brian K; Pruett, Greg S.
Subject: Fw: FATALITY FROM CONTACT

Have appropriate notifications occurred?

Geisha


From: Redacted
Sent: Friday, November 25, 2011 07:46 AM
To: CC CES CE ES&S Outage Escalation
Cc: Redacted
Subject: FATALITY FROM CONTACT

FYI

Outage: 456244 @ 00:51, Region Northern, Shasta District :
DESCHUTES 1101. Device 1580. Cust: 360. @ 0246 HRS PARKER RPTS
FATALITY FROM CONTACT, we will provide more information as it
becomes available.


Redacted

Pacific Gas and Electric Company
CES-Energy Solutions and Service

 530-896-4236

Fax: 530-896-4292

Business Customer Service 1-800-468-4743

 Internal 751-4236

Cell: 530-519-1303

Redacted



Please consider the environment before printing this e-mail.