

From: Cherry, Brian K  
Sent: 11/11/2011 10:37:27 AM  
To: 'mlc@cpuc.ca.gov' (mlc@cpuc.ca.gov); 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov);  
Bottorff, Thomas E (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TEB3);  
Horner, Trina (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TNHC)  
Cc:  
Bcc:  
Subject: Fw: Reportable CPUC Gas Incident

FYI

**From:** [Redacted]  
**Sent:** Thursday, November 10, 2011 09:33 PM  
**To:** UO EP Gas Incident Notify  
**Cc:** Lam, William Q (GE&O); Tang, Wai (GE&O); Corona, John M; Horner, Trina  
**Subject:** Reportable CPUC Gas Incident

At approximately 1905 hours, at Mission and Beale Streets in San Francisco, a PG&E construction crew was excavating at a 16-inch DFM when they inadvertently struck and broke a 2-inch steel drip line off of the DFM resulting in a release of gas. The operating pressure of the DFM was 55 psig. The flow of gas was stopped at 2045 hours. Repairs are nearly complete and relights will begin soon. Four customers lost service. Police are on scene and blocked off the area.

There was no ignition, injuries or fatalities as a result of this incident. Damages are less than \$50,000. This was reported to the CPUC at 2108 hours this evening due to the presence of Bay Area TV Channel 5 arrived on scene.

Please let me know if you require any additional information regarding this incident.

[Redacted]

Regulatory Compliance  
PG&E - Gas Engineering & Operations

[Redacted]