

From: Ramaiya, Shilpa R
Sent: 11/6/2011 6:03:43 PM
To: michelle.cooke@cpuc.ca.gov (michelle.cooke@cpuc.ca.gov);
julie.halligan@cpuc.ca.gov (julie.halligan@cpuc.ca.gov); sunil.shori@cpuc.ca.gov
(sunil.shori@cpuc.ca.gov); terrie.prosper@cpuc.ca.gov
(terrie.prosper@cpuc.ca.gov)
Cc: Doll, Laura (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=LRDD);
Horner, Trina (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=TNHC);
Dowdell, Jennifer (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=JKD5)
Bcc:
Subject: Re: Line 132 Hydrotest Failure

Here are two additional photos to give more context on size and location.

Shilpa

From: Ramaiya, Shilpa R
Sent: Sunday, November 06, 2011 5:46 PM
To: michelle.cooke@cpuc.ca.gov; julie.halligan@cpuc.ca.gov; sunil.shori@cpuc.ca.gov;
terrie.prosper@cpuc.ca.gov
Cc: Horner, Trina; Doll, Laura; Dowdell, Jennifer
Subject: RE: Line 132 Hydrotest Failure

Here is a picture that we just received. Also, The approx location is

Redacted

Redacted

More info to come.

Shilpa
415-509-7599

From: Ramaiya, Shilpa R
Sent: Sunday, November 06, 2011 5:15 PM
To: michelle.cooke@cpuc.ca.gov; julie.halligan@cpuc.ca.gov; sunil.shori@cpuc.ca.gov;
terrie.prosper@cpuc.ca.gov
Cc: Horner, Trina; Doll, Laura; Dowdell, Jennifer
Subject: RE: Line 132 Hydrotest Failure

Including Terrie as I'm hearing that media has been arriving. Redacted and Redacted from PG&E are heading there.

From: Ramaiya, Shilpa R
Sent: Sunday, November 06, 2011 5:12 PM

To: michelle.cooke@cpuc.ca.gov; julie.halligan@cpuc.ca.gov; sunil.shori@cpuc.ca.gov
Cc: Horner, Trina; Doll, Laura; Dowdell, Jennifer
Subject: Line 132 Hydrotest Failure

Michelle, Julie, Sunil,

I just learned of a hydrotest failure on T-31 that caused mud from the rupture to shut down part of Highway 280. No accidents and no injuries. It was at the corner of Redacted. And the pressure when it ruptured was above 500 psi.

More details to come. Quang Pham of the CPUC was informed as he was observing T-30.

3 of 4 highway lanes are now open.

Shilpa