

From: Cherry, Brian K  
Sent: 11/25/2011 1:04:07 PM  
To: 'mlc@cpuc.ca.gov' (mlc@cpuc.ca.gov); 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: Fw: FATALITY FROM CONTACT  
FYI

**From:** Williams, Geisha  
**Sent:** Friday, November 25, 2011 12:43 PM  
**To:** Cherry, Brian K  
**Subject:** Re: FATALITY FROM CONTACT

Here's what the text I received said.

CPUC Elec Incident: 3rd Party Fatality. NV division, City of Oakrun. 3rd party vehicle hit pole & wire fell on vehicle. Preliminary rpt is driver exited vehicle contacting energized 12kV wire resulting in fatal injuries.

**From:** Cherry, Brian K  
**Sent:** Friday, November 25, 2011 12:09 PM  
**To:** Williams, Geisha; Kiraly, Gregory; Lemler, Gregg  
**Cc:** Pruett, Greg S.  
**Subject:** Re: FATALITY FROM CONTACT

Thanks Geisha. When you hear more, please let me know and I can share it with the Commission.

**From:** Williams, Geisha  
**Sent:** Friday, November 25, 2011 11:59 AM  
**To:** Kiraly, Gregory; Lemler, Gregg  
**Cc:** Cherry, Brian K; Pruett, Greg S.  
**Subject:** Fw: FATALITY FROM CONTACT

Have appropriate notifications occurred?

Geisha

**From:** [Redacted]  
**Sent:** Friday, November 25, 2011 07:46 AM  
**To:** CC\_CES\_CE\_ES&S Outage Escalation  
**Cc:** [Redacted]  
**Subject:** FATALITY FROM CONTACT

FYI

Outage: 456244 @ 00:51, Region Northern, Shasta District : DESCHUTES 1101.  
Device 1580. Cust: 360. @ 0246 HRS PARKER RPTS FATALITY FROM CONTACT, we  
will provide more information as it becomes available.

Redacted



Please consider the environment before printing this e-mail.