From: Bottorff, Thomas E

Sent: 12/20/2011 8:49:04 AM

To: 'Clanon, Paul' (paul.clanon@cpuc.ca.gov)

Cc: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7);

michelle.cooke@cpuc.ca.gov (michelle.cooke@cpuc.ca.gov)

Bcc:

Subject: RE: Tonight's Power Outage at Candlestick Park

Ok; we'll call at 8:50

From: Clanon, Paul [mailto:paul.clanon@cpuc.ca.gov]

Sent: Tuesday, December 20, 2011 8:42 AM

To: Bottorff, Thomas E

Cc: Cherry, Brian K; michelle.cooke@cpuc.ca.gov

Subject: Re: Tonight's Power Outage at Candlestick Park

Thanks. Pls call 703-4392. Michelle and I'll both be there about 8:50.

On Dec 20, 2011, at 8:37 AM, "Bottorff, Thomas E" < TEB3@pge.com > wrote:

Paul,

After much internal discussion, Geisha's been advised not to send a note because several assertions cannot be confirmed. Nevertheless, we have a pretty good idea of what happened.

I would suggest that all of us, including Geisha, participate in a call as soon as you're ready. Please let me know what number to call.

Tom

From: Clanon, Paul [mailto:paul.clanon@cpuc.ca.gov]

Sent: Tuesday, December 20, 2011 8:14 AM

To: Bottorff, Thomas E

Cc: Cherry, Brian K; michelle.cooke@cpuc.ca.gov

Subject: Re: Tonight's Power Outage at Candlestick Park

Great. I'll read the note, then we can talk. Thx.

On Dec 20, 2011, at 8:02 AM, "Bottorff, Thomas E" < TEB3@pge.com > wrote:

Paul.

I just spoke with Geisha. She has the details and is drafting a note now. If you're available to speak with her, please let me know and I'll set up a call.

Tom

From: Cherry, Brian K

Sent: Tuesday, December 20, 2011 7:38 AM

To: 'paul.clanon@cpuc.ca.gov'

Cc: Bottorff, Thomas E; 'michelle.cooke@cpuc.ca.gov' **Subject:** Re: Tonight's Power Outage at Candlestick Park

I don't doubt that he is doing that. He was at the game last night too.

From: Clanon, Paul [mailto:paul.clanon@cpuc.ca.gov]

Sent: Tuesday, December 20, 2011 07:36 AM

To: Cherry, Brian K

Cc: Bottorff, Thomas E; michelle.cooke@cpuc.ca.gov

<michelle.cooke@cpuc.ca.gov>

Subject: Re: Tonight's Power Outage at Candlestick Park

If I were Tony right now I'd be sitting in my office looking at the clock and waiting for the first person to come in and tell me exactly what happened out there. This is corporate credibility time, and it's not a one-day sports story.

On Dec 20, 2011, at 7:31 AM, "Cherry, Brian K"

<<u>BKC7@pge.com</u>> wrote:

Honestly, we still haven't heard. I will shake the tree some more.

From: Clanon, Paul [mailto:paul.clanon@cpuc.ca.gov]

Sent: Tuesday, December 20, 2011 07:22 AM

To: Cherry, Brian K; Bottorff, Thomas E

Cc: Michelle Cooke < michelle.cooke@cpuc.ca.gov>
Subject: Re: Tonight's Power Outage at Candlestick

Park

Is Geisha just not telling? No way that's all PG&E knows. And is this auto-transfer switch's failure the first thing that went wrong, or is it a fallback device to go to a second circuit because the first one failed?

By the way, all of America (and no doubt Ed Randolph, watching the game at Señor Frog's in Cabo) has seen the flash in the parking lot and heard it described as a transformer blowing, complete with sparks.

On Dec 20, 2011, at 7:13 AM, "Cherry, Brian K" <BKC7@pge.com> wrote:

From: Corporate Relations Mailbox **Sent**: Monday, December 19, 2011

09:38 PM

To: All PG&E Mail Recipients; All PGE

Corp Employees

Subject: Tonight's Power Outage at

Candlestick Park

Colleagues:

Shortly before game time at Candlestick Park this evening, a power

stadium, followed by a second outage later in the game. Geisha W President for Electric Operations, issued the following statement:

"PG&E is working closely with the City and County of San Francis of Candlestick Park, to determine the cause of tonight's power out for both PG&E and the City and County has been to get the power and safely as possible and keep the power on through the rest of t exactly what happened and working to prevent something like this is very important to everyone involved."

Here are some of the details as we know them tonight:

According to preliminary reports, the auto-transfer switch owned b operate properly to switch load to the second circuit serving the stawas without power for nearly 10 minutes before power was restore outage impacted the stadium at approximately 6:45 p.m. and laste

•□□□□□□□ We are actively investigating the cause of both outaç
•□□□□□□□□ Crews located a power line down in the area and are if this was related to the first outage that impacted the park.
●□□□□□□□ There is no indication that PG&E equipment was invoutage.
●□□□□□□□□ While we have many customers at the stadium, Can only facility impacted.
●□□□□□□□□ As a common practice, PG&E always works with the of a major event, in this case the game, to prepare a quick and colto any potential issue.

Roger Frizzell

Vice President and Chief Communications Officer