



**Pacific Gas and  
Electric Company\***

**Bill Gibson**  
Director, Regulatory Compliance  
and Support  
Gas Operations

375 N. Wiget Lane,  
Walnut Creek, CA 94598  
Suite 250

925-974-4210  
Fax: 925-974-4102  
Internet: WLG3@pge.com

December 30, 2011

Ms. Michelle Cooke, Director  
Consumer Protection and Safety Division  
California Public Utilities Commission  
505 Van Ness Ave., Room 2005  
San Francisco, CA 94102-3298

Re: California Public Utilities Commission  
Self Identification and Correction Notice  
Contra Costa County, California – December 21, 2011

Dear Ms. Cooke:

The attached notification concerns a self identified non-compliance issue that PG&E is providing the Commission pursuant to Resolution ALJ-274.

On December 21, 2011 a PG&E mapping employee discovered that 16 plat maps had inadvertently not been included in the leak survey schedule resulting in distribution pipeline and services not leak surveyed within the five year time requirement which is a violation of 49 CFR 192.723(b)(2). Since this discovery, PG&E has taken immediate corrective actions as further described in the attached notice.

Please contact [Redacted] at [Redacted] or [Redacted] for any additional questions you may have regarding this notification.

Sincerely,

/S/

Bill Gibson

Attachment