Gas Transmission 2012 Direct Inspections & Hydrostatic Testing - Proposed Program Modifications





1



Objective:

 As a follow-up to the comments CPSD included in response to the Peninsula Pressure Restoration filing in late 2011, PG&E would like to coordinate with the CPSD to ensure that there is alignment in how pipeline direct inspection data is documented.



Direct Inspections Matrix

г		Excavation Reason											
	Legend:					Records Verification							
X - Required IN - If Needed FA - Failure Analysis		Design Need / Third Party Request		Hydrostatic Test		MAOP Validation		GIS Data		Class Location Verification		IM Analysis	
L		Existing	Proposed	Existing	Proposed	Existing	Proposed	Existing	Proposed	Existing	Proposed	Existing	Proposed
H-Form Section	Header			x	FA	X		X				Х	X
	1 - Data Before Coating Removal			х	FA	х		х				х	x
	2 - Data After Coating Removal			х	FA	x		х				х	X
	Excavation Drawing			x	FA	x		x				х	X
	External Corrosion Grid			IN	FA	IN		IN				IN	IN
	Internal Corrosion Grid			x	FA	x		X	- IN			x	X
	Coating Damage Details			IN	FA	IN		IN		- IN -	IN	IN	
	Corrosion Log			IN	FA	IN	1	IN X X			IN	IN	
	Photo Log			X	FA	x					x	X	
	3 - Recoat Information			x	FA	x					_	x	X
	4 - Repair Data			IN	FA	IN	1	IN	_			IN	IN
	Site Map			x	FA	x	1	x			x	x	
ABI Report	ABI Report	IN	IN	x	IN	x	IN	x	IN	IN	IN	x	IN
	Header Data	x	x	x	x		x		x	X	x		
	Initial Leak Data												
	Mapping Data												
	HCA Data												
	Pipe Data	х	X	x	x		x		x	X	x		
Ę	Repair Data	IN	IN	IN	IN		IN		IN	IN	IN		
AFo	General Inspection Data	x	x	x	x		x		x	x	x		
	Cathodic Protection Condition												
	Metallic Pipe Condition	x	x	х	x		x		X	X	x		
	Plastic Pipe Condition												
	Gas Quarterly Incident Data												
	Location Sketch	x	x	x	x		x		x	x	x		
S	Specific Requested Report			IN	IN	IN	IN	IN	IN	IN	IN	IN	IN
	Long Seam Validation (DSAW vs. SSAW)			IN	IN	IN	IN	iN	IN	IN	IN	IN	IN
Ρ	Macro Etching				IN		IN		IN	IN	IN		
	Destructive Testing			x	IN	IN	IN						



PG&E is proposing direct inspection logic based on findings rather than prescription. Following are examples that would trigger a more in depth inspection:

- $\checkmark\,$ Any evidence of missing or disbonded wrap
- ✓ Isolated or clustered corrosion pitting
- ✓ Seam defect (e.g., missing weld, mis-alignment, cracking)
- ✓ Seam placement in 5 to 7 pm position
- $\checkmark\,$ Downstream of and within 20 miles of compressor station
- $\checkmark\,$ Visible dents, laminations or other anomalies
- ✓ Any gouges, scrapes or signs of third-party damage
- ✓ Hydrostatic test rupture or leak

4



	2011 Program	Proposed Modification for 2012	Notes
Hydrostatic Test Operator	Use State Fire Marshall certified hydrostatic test operators	Allow PG&E crews to conduct some hydrostatic tests with certification provided by RCP; Use State Fire Marshall certified hydrostatic test operators when using a contractor	PG&E crews have significant experience conducting hydrostatic tests and could lower the costs for some tests
Test Pressure Verification	Confirmed recommended target max test pressures for each test based on mil test pressures provided from Kiefner and Associates	Engage Kiefner and Associates for subject matter expertise input in unique test situations	Kiefner and Associates has provided PG&E with mill test pressure data for most expected pipe types and vintages. Consult Kiefner on exceptions only.
Test Procedure Certification	Engage Bureau Veritas to certify that every test is conducted according to hydrostatic test plan	Do not engage Bureau Veritas for 2012 work	RCP certification is sufficient for third party verification