



## **Certificate of Compliance**

### **Pacific Gas and Electric Company**

### **Hydrostatic Test Program**

**This certificate is issued pursuant to the requirements of PG&E  
Hydrostatic Testing Procedure A-37, PG&E Site Specific Test  
Procedures, PG&E Site Specific Piping Design and Test Requirements  
A-34**

**The hydrostatic testing of the pipeline section below has been observed  
and found to be in compliance with the site-specific test procedures.**

**Section:** Pacific Gas and Electric Pipeline Section: Line-400-3 / T-93A

**Project Name:** PG&E Hydrostatic Test Program

**Owner of Project:** Pacific Gas and Electric Company

**Locality:** Antioch, CA

**Program Manager:** Mark A. Tobin

Digitally signed by Mark A. Tobin  
DN: cn=Mark A. Tobin, o=Bureau Veritas North  
America, ou=Power and Utilities,  
email=mark.tobin@us.bureauveritas.com, c=US  
Reason: I have reviewed this document  
Date: 2012.01.17 14:21:09 -0500

**Date:** 01-17-2012

Bureau Veritas North America, Inc.  
180 Promenade Circle, Suite 150  
Sacramento, CA, 95834