



Certificate of Compliance

Pacific Gas and Electric Company

Hydrostatic Test Program

**This certificate is issued pursuant to the requirements of PG&E
Hydrostatic Testing Procedure A-37, PG&E Site Specific Test
Procedures, PG&E Site Specific Piping Design and Test Requirements
A-34**

**The hydrostatic testing of the pipeline section below has been observed
and found to be in compliance with the site-specific test procedures.
The dew point was recorded at -65°F, which is outside the -20°F to -40°F
as stated in A-37.**

Section: Pacific Gas and Electric Pipeline Section: Line-300A / T-65B

Project Name: PG&E Hydrostatic Test Program

Owner of Project: Pacific Gas and Electric Company

Locality: Tres Pinos, CA

Program Manager: _____

Mark A. Tobin

Digitally signed by Mark A. Tobin
DN: cn=Mark A. Tobin, o=Bureau Veritas North
America, ou=Power and Utilities,
email=mark.tobin@us.bureauveritas.com, c=US
Reason: I have reviewed this document
Date: 2012.01.10 13:53:22 -0800

Date: _____

01-10-2012

**Bureau Veritas North America, Inc.
180 Promenade Circle, Suite 150
Sacramento, CA, 95834**