

From: Cherry, Brian K  
Sent: 1/24/2012 3:03:56 PM  
To: 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: FW: Reportable Gas Incident at [Redacted], San Bruno

**From:** [Redacted]  
**Sent:** Tuesday, January 24, 2012 02:58 PM  
**To:** UO EP Gas Incident Notify  
**Cc:** Kubota, Jodie; [Redacted]  
**Subject:** Reportable Gas Incident at [Redacted] San Bruno

PG&E was notified at 13:17 on 1/24/12 of a third-party dig-in near [Redacted], San Bruno. The third party was excavating and struck a 2-inch gas distribution main. PG&E was on-site by 13:25. Gas was shut-off by 14:13. An emergency USA notification had been submitted and marks are currently being reviewed.

There were no injuries and damages are not expected to exceed \$50,000. The only reason for reporting this incident is due to media on site. Therefore, this incident was reported to the CPUC by 14:39.

If you have any questions, please contact [Redacted]