

From: Clanon, Paul
Sent: 1/5/2012 10:35:21 AM
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)
Cc:
Bcc:
Subject: Re: X-1116 Outage

Thx for the quick word.

On Jan 5, 2012, at 10:28 AM, "Cherry, Brian K" <BKC7@pge.com> wrote:

A dig-in.....

From: Dashner, Andrew M
Sent: Thursday, January 05, 2012 10:28 AM
To: SF_Update
Cc: Redacted
Subject: FW: X-1116 Outage

X-1116 Update: All upon arrive, T-men found a dig-in at Redacted. There were no 3rd party injuries as a result of the dig-in. Operations is in the process of restoring customers now. More to come.

Andy Dashner

From: Dashner, Andrew M
Sent: Thursday, January 05, 2012 10:11 AM
To: SF_Update
Subject: X-1116 Outage

All,

We have an OCB level outage on the X-1116 affecting 6926 customers in the Western Addition district. First no light was at 09:58. We have multiple T-men/C-men and an M&C crew enroute. We also have an reported hazard of "heard explosion" on the Redacted. More to come.

Andy Dashner