

From: Cherry, Brian K
Sent: 1/17/2012 7:14:45 AM
To: 'pac@cpuc.ca.gov' (pac@cpuc.ca.gov)
Cc:
Bcc:
Subject: Fw: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Here is the info

From: [Redacted]
Sent: Tuesday, January 17, 2012 03:22 AM
To: SF_Update
Subject: Re: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

All but 18 customers picked up. Crew on site with generator.

[Redacted]

From: [Redacted]
Sent: Tuesday, January 17, 2012 12:41 AM
To: [Redacted]
Subject: RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Update, once Transformer is isolated all 332 customers will be picked up on the Y-1135 circuit. Still waiting for crew.

[Redacted]

Bay Area Restore & Control Lead Supervisor

Distribution System Operations

cell: [Redacted]

From: [Redacted]
Sent: Monday, January 16, 2012 11:43 PM
To: SF_Update
Subject: RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Outage on Y-1135, NG Transformer found at Pacific and Lyon. Crew in route. T-Men on site. Erroneously reported by public media as a gas explosion. No Gas Odors in the area. Operations will attempt to pick up as many of the 332 customers as possible.

[Redacted]

Bay Area Restore & Control Lead Supervisor

Distribution System Operations

cell: [Redacted]

From: [Redacted]
Sent: Monday, January 16, 2012 11:20 PM
To: SF_Update
Subject: RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Media Inquiries on Explosion in a vault. Hazard tag received and personnel investigating vault explosion. Radio advertizes gas odor but PG&E personnel have not found such odor. Outage impacting 2900 block of Pacific Ave, 3200 block of Jackson, 2800 block of Broadway.

[Redacted]
Bay Area Restore & Control Lead Supervisor

Distribution System Operations

cell: [Redacted]

From: [Redacted]
Sent: Monday, January 16, 2012 10:52 PM
To: SF_Update
Subject: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

332 customers are experiencing an outage. the First no Light came in at 2206. T-Men and Cablemen being dispatched to this outage

[Redacted]
Bay Area Restore & Control Lead Supervisor

Distribution System Operations

cell: [Redacted]