

From: Clanon, Paul  
Sent: 1/17/2012 7:27:03 AM  
To: Cherry, Brian K (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=BKC7)  
Cc:  
Bcc:  
Subject: Re: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206  
Thx.

On Jan 17, 2012, at 7:14 AM, "Cherry, Brian K" <BKC7@pge.com> wrote:

Here is the info

**From:** Redacted  
**Sent:** Tuesday, January 17, 2012 03:22 AM  
**To:** SF\_Update  
**Subject:** Re: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

All but 18 customers picked up. Crew on site with generator.

Redacted

**From:** Redacted  
**Sent:** Tuesday, January 17, 2012 12:41 AM  
**To:** Redacted  
**Subject:** RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Update, once Transformer is isolated all 332 customers will be picked up on the Y-1135 circuit. Still waiting for crew.

Redacted

*Bay Area Restore & Control Lead Supervisor*

*Distribution System Operations*

cell: Redacted

---

**From:** Redacted  
**Sent:** Monday, January 16, 2012 11:43 PM  
**To:** SF\_Update  
**Subject:** RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Outage on Y-1135, NG Transformer found at Pacific and Lyon. Crew in route. T-Men on site. Erroneously reported by public media as a gas explosion. No Gas Odors in the area. Operations will attempt to pick up as many of the 332 customers as possible.

Redacted

*Bay Area Restore & Control Lead Supervisor*

*Distribution System Operations*

cell: Redacted

---

**From:** Redacted

**Sent:** Monday, January 16, 2012 11:20 PM

**To:** SF\_Update

**Subject:** RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

Media Inquiries on Explosion in a vault. Hazard tag received and personnel investigating vault explosion. Radio advertizes gas odor but PG&E personnel have not found such odor. Outage impacting 2900 block of Pacific Ave, 3200 block of Jackson, 2800 block of Broadway.

Redacted

*Bay Area Restore & Control Lead Supervisor*

*Distribution System Operations*

cell: Redacted

---

**From:** Redacted

**Sent:** Monday, January 16, 2012 10:52 PM

**To:** SF\_Update

**Subject:** San Francisco Outage 495553- Y-1135 circuit outage FNL 2206

332 customers are experiencing an outage. the First no Light came in at 2206. T-Men and Cablemen being dispatched to this outage

Redacted

*Bay Area Restore & Control Lead Supervisor*

*Distribution System Operations*

cell: Redacted

