

From: Cherry, Brian K
Sent: 1/5/2012 10:28:14 AM
To: Clanon, Paul (paul.clanon@cpuc.ca.gov) (paul.clanon@cpuc.ca.gov); Michelle
Cooke (mlc@cpuc.ca.gov) (mlc@cpuc.ca.gov)

Cc:

Bcc:

Subject: FW: X-1116 Outage

A dig-in.....

From: Dashner, Andrew M
Sent: Thursday, January 05, 2012 10:28 AM
To: SF_Update
Cc: [Redacted]
Subject: FW: X-1116 Outage

X-1116 Update: All upon arrive, T-men found a dig-in at [Redacted]. There were no 3rd party injuries as a result of the dig-in. Operations is in the process of restoring customers now. More to come.

Andy Dashner

From: Dashner, Andrew M
Sent: Thursday, January 05, 2012 10:11 AM
To: SF_Update
Subject: X-1116 Outage

All,

We have an OCB level outage on the X-1116 affecting 6926 customers in the Western Addition district. First no light was at 09:58. We have multiple T-men/C-men and an M&C crew enroute. We also have an reported hazard of "heard explosion" on the [Redacted] [Reda]. More to come.

Andy Dashner