



Pacific Gas and Electric Company
Gas Pipeline Facilities Strength Test Pressure Report
 (For Pipeline Facilities Designed to Operate over 100 PSIG)

62-4921 (Rev. 2/04)
 California Gas Transmission
 (Use in Accordance With Gas Standard A-34 and GO 112-D)

FINAL

Sheet 1 of 1

PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)									
Feeder Main Number, Line Number, or Station Name		Area		Division/District		Job Number		Date Job Authorized	
L-300B		3		Hollister		41497337		8/10/11	
Description of Job -- Include Reference Drawing Numbers, and Pipeline Mileposts TEST 2 - Hydrostatically test tie-in piping, hydrostatic test piping and existing 34" L-300B Existing pipeline material listed are from the "Material of Record" (refer to Dwg. 41497337 Sheet 4) Hydrotest L-300B from MP 445.49 - 446.50 Hollister, CA (Test section 87C)									
Location Class		Design Factor (F)		MAOP to be Established for this Piping by this Test		Future Design Pressure			
2		0.60		631		631 PSIG			
STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)		Max. Elevation: 610 Ft.		Static Head Calculation		0.433 X Elev. Diff. = 31 PSIG			
		Min. Elevation: 538 Ft.		For Water					
		Elev. Diff.: 72 Ft.		Other (Specify)		X Elev. Diff. = PSIG			
Pipe Specification			Footage to Be Tested	Pipe Spec. and Footage Verified In Field	% of SMYS			Pressure to Give 90% SMYS	
Size O.D.	W.T.	API or ASTM Grade Long Seam (ERW, DSAW, Seamless, Etc.)			At MAOP	At Min. Test Press.	At Max. Test Press.		
34.00	0.375	API 5L, GR X-65, DSAW (item#102)	54'	K.L.G. 43.5	44.01	66.05	71.91	1291	
34.00	0.344	API 5L, GR X-52, DSAW (item#1)	5358'	K.L.G. M.D.R.	59.97	90.00	97.98	947	
34.00	0.500	API 5L, GR X-65 DSAW	36'	K.L.G.	33.01	49.54	53.93	1720	
Minimum Test Pressure @ Max. Elevation		947 PSIG		Test Fluid To Be Used: WATER	MINIMUM TEST DURATION			8 HOURS	
Maximum Test Pressure @ Min. Elevation		1031 PSIG			- UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34)				
Redacted		8/10/2011		For Information or Changes, Call: Redacted		Approved By: Redacted		Date: 8/12/11	
PART II - TEST DATA (TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)					Note: Minimum test pressure and duration are not to be changed without written approval.				
Time and Date Test Pressure Reached	11:02 am 10-5-2011	Elevation at Test Point	561 FT	Min. Required Test Press. At Test Point (1)	968 PSIG	Max. Allowable Test Press at Test Point (4)	1021 PSIG		
Time and Date Test Ended	7:17 pm 10-5-2011	Max. Elevation in Test Section	610 FT	Min. Indicated Test Pressure (2)	998 PSIG	Max. Indicated Test Pressure (5)	1003 PSIG		
Actual Duration of Test	8 hours 15	Min. Elevation in Test Section	538 FT	Min. Test Pressure at Max. Elevation (3)	976.8 PSIG	Max. Test Pressure at Min. Elevation (6)	1012.9 PSIG		
Test Fluid Used: water			Pipe Specification and Footage Verified (See Part I): K.L.G. A-603						
Make, Range, and Serial No. of Pressure Recording Gauge		Date Last Calibrated	Make, Range, and Serial No. of Dead Weight Tester (See Note 7)		Date Last Calibrated				
Barton 0-3000 200A-175572		6-7-2011	Chandler 50-3000 6106		5-19-2011				
Test Supervised By: Redacted		Date: 10-5-2011	Approved By: [Signature]		Date: 10-13-11				
PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.									
NOTES: (1) Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I. (2) Use lowest pressure on test gauge at any time during test. (3) Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure. (4) Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I. (5) Highest pressure on test gauge at any time during test. (6) Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure. (7) A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.					DISTRIBUTION JOB FILE (AT SPONSORING ORGANIZATION) GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT PROJECT MANAGER/PROJECT ENGINEER TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB) RECORDS SECTION (WC), GSM&TS REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING				