



Certificate of Compliance Pacific Gas and Electric Company **Hydrostatic Test Program**

**This certificate is issued pursuant to the requirements of PG&E
Hydrostatic Testing Procedure A-37, PG&E Site Specific Test
Procedures, PG&E Site Specific Piping Design and Test Requirements
A-34**

**The hydrostatic testing of the pipeline section below has been observed
and found to be in compliance with the site-specific test procedures.**

Section: Pacific Gas and Electric Pipeline Section: Line-132 / T-24

Project Name: PG&E Hydrostatic Test Program

Owner of Project: Pacific Gas and Electric Company

Locality: Milpitas, CA

Program Manager: **Mark A.
Tobin**

Digitally signed by Mark A. Tobin
DN: cn=Mark A. Tobin, o=Bureau Veritas
North America, ou=Power and Utilities,
email=mark.tobin@bureauveritas.com,
c=US
Reason: I have reviewed this document
Date: 2012.01.09 09:35:30 -0800

Date: 01-09-2012

Bureau Veritas North America, Inc.
180 Promenade Circle, Suite 150
Sacramento, CA, 95834