



Certificate of Compliance

Pacific Gas and Electric Company Hydrostatic Test Program

**This certificate is issued pursuant to the requirements of PG&E
Hydrostatic Testing Procedure A-37, PG&E Site Specific Test
Procedures, PG&E Site Specific Piping Design and Test Requirements
A-34**

**The hydrostatic testing of the pipeline section below has been observed
and found to be in compliance with the site-specific test procedures. The
dew point was recorded at -67.5°F, which is outside the -20°F to -40°F as
stated in A-37.**

Section: Pacific Gas and Electric Pipeline Section: Line-300A / T-67B

Project Name: PG&E Hydrostatic Test Program

Owner of Project: Pacific Gas and Electric Company

Locality: Morgan Hill, CA

Program Manager: Mark A. Tobin

Digitally signed by Mark A. Tobin
DN: cn=Mark A. Tobin, o=Bureau Veritas North America,
ou=Power and Utilities,
email=mark.tobin@bureauveritas.com, c=US
Serial: 1, Reason: I have reviewed this document
Date: 2012.01.25 15:38:41 -0500

Date: 01-25-2012

Bureau Veritas North America, Inc.
180 Promenade Circle, Suite 150
Sacramento, CA, 95834