

From: Cherry, Brian K
Sent: 1/17/2012 10:41:24 AM
To: Clanon, Paul (paul.clanon@cpuc.ca.gov) (paul.clanon@cpuc.ca.gov)
Cc:
Bcc:
Subject: FW: Region BA, San Francisco Large Outage

FYI

-----Original Message-----

From: Redacted
Sent: Tuesday, January 17, 2012 10:30 AM
To: Elec Ops DO Outage Communication Bay
Subject: FW: Region BA, San Francisco Large Outage

UPDATE:

E-1107 new outage is not accurate, stray calls driving an inferred outage.
Castro 402 4kV might have to be de-energized for a short duration due to the 12kV wire down.

H-1109 customers will remain out, OH crew enroute(crew on-site is UG) to cut jumpers and reduce impact.

More to follow

-----Original Message-----

From: Redacted
Sent: Tuesday, January 17, 2012 10:19 AM
To: Elec Ops DO Outage Communication Bay
Subject: FW: Region BA, San Francisco Large Outage

UPDATE:

E-1107 - 4820 customers restored.
Continued restoration efforts, 4kV customers still out Crew on-site

More to follow

-----Original Message-----

From: Redacted
Sent: Tuesday, January 17, 2012 9:58 AM
To: Elec Ops DO Outage Communication Bay
Subject: FW: Region BA, San Francisco Large Outage

At 0933 outage on E-1107 related to H-1109 circuit outage.
Wire down and isolated.

T-Men on-site and restoring.

More to follow.

-----Original Message-----

From: OIS APP Admin [<mailto:cadadmin@oisprddb01b.comp.pge.com>]

Sent: Tuesday, January 17, 2012 9:39 AM

To: [Redacted]

Subject: Region BA, San Francisco Large Outage

Large Outage in Region BA, San Francisco district 1 customers affected circuit

District	Outage#	Customers	Circuit
-----	-----	-----	-----

Summary of all San Francisco control center outages by district and device category

District	Category	Outages	Customers
-----	-----	-----	-----
Peninsula	Customer	1	1
San Francisco	Customer	7	7
San Francisco	Device	4	5793
San Francisco	Transformer	2	72
Skyline	Customer	1	1

OIS Paging System