From:	Cherry, Brian K
Sent:	1/17/2012 7:14:45 AM
To:	'pac@cpuc.ca.gov' (pac@cpuc.ca.gov)
Cc:	
Bcc:	
Subject:	Fw: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206
Here is th	e info
To: SF_Up	sday, January 17, 2012 03:22 AM
All but 18	customers picked up. Crew on site with generator.
Redacted	
Redacted	
To Redacte	sday, January 17, 2012 12:41 AM
	once Transformer is isolated all 332 customers will be picked up on the Yuit. Still waiting for crew.
Redacted	
Bay Area	Restore & Control Lead Supervisor
Distributio	on System Operations
Redacted	
To: SF_Up Subject: I Outage con site. I	day, January 16, 2012 11:43 PM
Redacted	

Bay Area Restore & Control Lead Supervisor
Distribution System Operations
Redacted
From Redacted  Sent: Monday, January 16, 2012 11:20 PM  To: SF_Update  Subject: RE: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206
Media Inquiries on Explosion in a vault. Hazard tag received and personnel investigating vault explosion. Radio advertizes gas odor but PG&E personnel have not found such odor. Outage impacting 2900 block of Pacific Ave, 3200 block of Jackson, 2800 block of Broadway.
Redacted  Bay Area Restore & Control Lead Supervisor
Distribution System Operations
Redacted
From: Redacted Sent: Monday, January 16, 2012 10:52 PM To: SF_Update Subject: San Francisco Outage 495553- Y-1135 circuit outage FNL 2206
332 customers are expieriencing an outage. the First no Light came in at 2206. T-Men and Cablemen being dispatched to this outage
Redacted  Bay Area Restore & Control Lead Supervisor
Distribution System Operations
Redacted