

Account ID: [Redacted]  
Hm Ph:  
Bus Ph:  
Cont Ph: [Redacted]  
Name: [Redacted]  
Address: [Redacted]  
City: SAN JOSE

Prem Tyne: COM/IND  
Bus Activty:  
Home Area: [Redact]  
Sub Area: [Redac]  
Check Dinit:  
SI  
IS  
Gas Sd Id  
Elec Sd Id  
MtrDd Route: MVD02

Completion Information

PM Information

Job Code: [Redacted]  
Eld Act Type 1: CASLEAKM Comp Code 4 4121 - C Lock Outside Modified Lock  
Eld Act Type 2: Comp Code 2  
Eld Act Type 3: Comp Code 2  
Eld Act Type 4: Comp Code 4  
EAC Ref: 1  
MR:  
CR:

PM Order:  
PM Operat:  
Order Dates/Misc  
Date Work: 10/10/04  
App Start Time: 08:00  
App End Time: 08:00  
Call E. D. I.: 10/10/04  
M. I. I. I.: 0100017

New Hazards / Summary / Misc

Check Dinit:  
Tot Amt Order:  
Cost Only Flag:

Technical Information

AXC OK--SMELLING GAS NEAR METER--SEE CUSTODIAN--BY CAFETERIA DOOR BEHIND SCHOOL

---

**FMR Ord Detail:**

BEHIND CAFETERIA FIND JANITOR 4 ANOTHER E IN

**FMR Completion:**

**Diagnosis:**

**Comment:**

RUSTED HOLE IN DIP POT REFERR TO OMC. FOUND STOPCOCK LEAKING GOING INTO BLDG, ADV SCHOOL DISTRICT

**Findings:**

AND FOUND SMALL FOAMER AT OVEN IN CAFETERIA.

**Recommendations:**