

Account ID: Redacted
Hm Ph: Redacted
Bus Ph: Redacted
Cont Ph: Redacted
Name: Redacted
Address: Redacted
City: SAN JOSE

Prem Tyne COM/IND
Bus Activty 611110
Home Area Redacted
Sub Area Redacted
Check Dinit
SI
IS
Gas Sn Id 0321825005
Elec Sn Id
MtrDl Route M/P02

Completion Information

PM Information

Job Code: 4190 - C Unspecified Outside
Eld Act Type 1: Redacted Comp Code 4 4190 - C Unspecified/Unknown Order
Eld Act Type 2: Redacted Comp Code 2
Eld Act Type 3: Redacted Comp Code 2
Eld Act Type 4: Redacted Comp Code 4
EAC Referral 1
MR:
CR:

PM Order
PM Operation
Order Dates/Misc
Date Worked: 1/22/11
App Start Time: 08:00
App End Time: 08:00
Call # B: 100/11
M: 1100/11

New Hazards / Surveys / Misc

Check Dinit
Tot Amt Order
Cost Only Flag
Technical Information

AXS OK; XST Redacted METER CLICKING SOUND AND METER SPINNING ????? PER MN OFFIC

FMR Ord Detail:
BEHIND CAFETERIA

FMR Completion:

Dispatch:

Comment:
ADVSD OFFICE OF SOUND EQUALS DEMAND FOR GAS--SWEPT AREA 0% READS

Remarks:
ISSUED F/UP TAG FOR GAS M/C--2 SMALL FUZZ LEAKS ON INLINE FILTER --NON HAZARDOUS