

From: [Redacted]
Sent: 2/21/2012 4:28:42 PM
To: 'Cooke, Michelle' (michelle.cooke@cpuc.ca.gov)
Cc: 'Lee, Dennis M.' (dennis.lee@cpuc.ca.gov); Ramaiya, Shilpa R (/o=PG&E/ou=Corporate/cn=Recipients/cn=SRRd); 'Shori, Sunil' (sunil.shori@cpuc.ca.gov); 'Robertson, Michael' (michael.robertson@cpuc.ca.gov); [Redacted] (/O=PG&E/OU=CORPORATE/CN=RECIPIENTS/CN=[Redact]); Yee, Frances (/o=PG&E/ou=Corporate/cn=Recipients/cn=FSC2)
Bcc:
Subject: 2/13/12 - Llano Seco Self-Identification Follow-up

Ms. Cooke:

This letter is an update to the Llano Seco inadequate odorization non-compliance notification provided to you on February 13, 2012.

Following the notification provided to you on February 13, 2012, we were informed that there were three additional non-hazardous leaks identified from the leak investigation conducted on February 8, 2012. Two leaks were identified on meter sets and one was on a water heater flex hose. All three leaks were repaired on February 8, 2012. This information was inadvertently omitted from our initial notification and we apologize for the oversight.

Sincerely,

[Redacted]

Regulatory Compliance
PG&E - Gas Engineering & Operations

[Redacted]