

From: [Redacted]  
Sent: 6/26/2012 3:11:48 PM  
To: Ramaiya, Shilpa R (/o=PG&E/ou=Corporate/cn=Recipients/cn=SRRd); 'Shori, Sunil' (sunil.shori@cpuc.ca.gov)  
Cc:  
Bcc:  
Subject: RE:

Sunil,

Prior to filing our request for pressure restoration, PG&E performed aerial surveys of L131-30 to determine if any overbuilds existed along the pipeline. We did not find anything concerning at the time; however, from the aerial photographs, it can be difficult to determine if any nearby buildings actually encroach on the right-of-way. Therefore, PG&E is currently mobilizing crews to perform an encroachment review of L131-30. We expect to have this complete by July 14 and will share the results with you.

In order to move this filing along, it may make sense for you to write your filing review and say it is contingent upon PG&E's encroachment review. Since this line provides summer peaking load, we are very interested in a restoration when safe to do so in early August.

Regarding your other question, for Line 132, we reviewed MP 3.00-13.00 and for Line 153, MP 10.00-20.00.

Please let me know if you have any questions.

Thank you,

[Redact]

-----Original Message-----

From: Shori, Sunil [mailto:sunil.shori@cpuc.ca.gov]

Sent: Saturday, June 23, 2012 3:34 PM

To: Ramaiya, Shilpa R

C [Redacted]

Subject:

Shilpa,

What recent patrols or surveys has PG&E performed to assess if there are any encroachment issues on the entire length of Line 131 and, in particular, the portion of Line 131 for which PG&E is seeking to restore pressure? In addition, we would like to obtain the start and end milepoints for the encroachment pilot projects initiated by PG&E on Lines 132 and 153.

Thanks, Shilpa.

Sunil