

**PACIFIC GAS AND ELECTRIC COMPANY
Gas Pipeline Safety OIR
Rulemaking 11-02-019
Data Response**

PG&E Data Request No.:	LocalUnions246-342_003-10		
PG&E File Name:	GasPipelineSafetyOIR_DR_LocalUnions246-342_003-Q10		
Request Date:	January 17, 2012	Requester DR No.:	003
Date Sent:	January 27, 2012	Requesting Party:	Plumbers/Pipe Fitters/Steamfitters Local Unions 246/342
PG&E Witness:	Todd Hogenson	Requester:	Sarah Grossman- Swenson

QUESTION 10

In the Implementation Plan, at page 19, PG&E states that it plans to replace 186 miles of pipeline in Phase I. At page 21, PG&E states that it plans to retrofit 199 miles of pipeline for ICI in Phase I. Do any of these pipeline segments overlap in any way? If so, please identify each replacement segment that overlaps with each retrofit segment. Please explain why they overlap.

ANSWER 10

In the second sentence of the question, the phrase "ICI" is used, which PG&E believes is meant to be "ILI" or in-line inspection. There is no overlap between the Phase 1 pipeline replacement segments and the ILI retrofit segments.