

From: [Redacted]
Sent: 6/25/2012 1:44:07 PM
To: Shori, Sunil (SKS@cpuc.ca.gov)
Cc: Ramaiya, Shilpa R (/o=PG&E/ou=Corporate/cn=Recipients/cn=SRRd); [Redacted]
[Redacted]
Bcc:
Subject: Gas Line 131-30 -- Weld Inspection Documents update

Sunil:

Following our conference call on Friday, we revised the Daily Field Weld Summary Report form as you suggested to separate Preheat & Interpass Temperature from Post (weld) Heat Treatment.

Also, we added the weld inspector's OQ date or CWI number to the bottom of the form to make it easier to confirm that the inspector is qualified.

The revisions to the form and the training materials are attached above.

Call if you have questions [Redacted]

[Redacted]