



Pacific Gas and Electric Company
Gas Pipeline Facilities Strength Test Pressure Report
 (For Pipeline Facilities Designed to Operate over 100 PSIG)

62-4921 (Rev. 2/04)
 California Gas Transmission
 (Use in Accordance with Gas Standard A-34 and GO 112-D)

Sheet **1** of **1**

PART I - DESIGN DATA (TO BE PREPARED BY PROJECT ENGINEER)										
Feeder Main Number, Line Number, or Station Name L-132		Area 1		Division/District Redacted		Job Number 41497358		Date Job Authorized July 16, 2012		
Description of Job -- include Reference Drawing Numbers, and Pipeline Mileposts Test 2 (A - B) -- Hydrostatically test tie-in pieces, hydrostatic test piping and existing 30" L-132. Existing pipeline material listed; ie. Pipe, elbows, sleeves are from the "Material of Record" (refer to Dwg 41497358, sheet 7 of 7). Revision 1 - Updated for 2012 construction. Hydrotest L-132 from MP Redacted (TIM-037-11)										
Location Class 1,3		Design Factor (F) .5		MAOP to be Established for this Piping by this Test 300 PSIG		Future Design Pressure 300 PSIG				
STATIC HEAD DUE TO ELEVATION DIFFERENCE (WHERE APPLICABLE)		Max. Elevation 1130 Ft.		Static Head Calculation		For Water 0.433 X Elev. Diff. = 401 PSIG				
		Min. Elevation 206 Ft.		Other (Specify)		X Elev. Diff. = PSIG				
		Elev. Diff. 924 Ft.								
Pipe Specification				Footage to Be Tested	Pipe Spec. and Footage Verified In Field	% of SMYS			Pressure to Give 90% SMYS	
Size O.D.	W.T.	API or ASTM Grade Long Seam (ERW, DSAW, Seamless, Etc.)				At MAOP	At Min. Test Press.	At Max. Test Press.		
30.00	0.375	Pipe, API 5L X-65, SAWL (item #103)		37'		18.46	27.69	53.85	1463	
30.00	0.375	Elbow, Y-60, LR (item #119)		4 Ea.		20.00	30.00	58.33	1350	
30.00	0.375	Pipe, API 5L X-52, DSAW (item #1)		4909'		23.08	34.62	67.31	1170	
30.00	0.375	Elbow, GR B*, LR (item #4)		6 Ea.		34.29	51.43	100.00	788	
30.00	0.500	Elbow, 30000 SMYS*, SR (item #5)		2 Ea.		30.00	45.00	87.50	900	
30.75	0.375	Sleeve, X-52 (item #8)		3 Ea.		23.65	35.48	68.99	1142	
30.00	0.375	Pipe, API 5L X-52, SMLS (item #14)		4'		23.08	34.62	67.31	1170	
30.00	0.375	Insulating Joint, ANSI 300 (item #15)		1 Ea.		-	-	-	-	
Minimum Test Pressure @ Max. Elevation		450 PSIG		Test Fluid To Be Used WATER		MINIMUM TEST DURATION - UNDER 30% SMYS (1 HR. MINIMUM) - 30% SMYS & OVER (8 HRS. MINIMUM) - PREINSTALLATION TEST (SEE ATTACHMENT 'A', GAS STD. A-34)			8 HOURS	
Maximum Test Pressure @ Min. Elevation		875 PSIG								
Prepared By: Redacted		Date: 7/16/12		For Information or Changes, Call: Redacted		Date: 7-16-12				
PART II - TEST DATA (TO BE PREPARED BY PERSON SUPERVISING TEST AT TIME OF TEST)						Note: Minimum test pressure and duration are not to be changed without written approval.				
Time and Date Test Pressure Reached		Elevation at Test Point		FT	Min. Required Test Press. At Test Point (1)	PSIG	Max. Allowable Test Press at Test Point (4)		PSIG	
Time and Date Test Ended		Max. Elevation in Test Section		FT	Min. Indicated Test Pressure (2)	PSIG	Max. Indicated Test Pressure (5)		PSIG	
Actual Duration of Test		Min. Elevation in Test Section		FT	Min. Test Pressure at Max. Elevation (3)	PSIG	Max. Test Pressure at Min. Elevation (6)		PSIG	
Test Fluid Used				Pipe Specification and Footage Verified (See Part I)						
Make, Range, and Serial No. of Pressure Recording Gauge			Date Last Calibrated		Make, Range, and Serial No. of Dead Weight Tester (See Note 7)			Date Last Calibrated		
Test Supervised By:				Date:		Approved By:			Date:	
PUT SCHEMATIC PIPING SKETCH ON BACK OF THIS SHEET										
SHOW LOCATION OF FACILITY TESTED, MINIMUM AND MAXIMUM ELEVATION IN FEET, MILE POINTS, VALVE NUMBERS AND INCORPORATED AREAS. USE AN ADDITIONAL SHEET IF NECESSARY (SHOW REFERENCE NUMBERS ON FACE OF ALL DRAWINGS AND ATTACHMENTS). FOR STATION PIPING, FABRICATED UNITS AND SHORT SECTIONS OF PIPE, ALSO SHOW A DETAILED SKETCH OF EACH ASSEMBLY TESTED.										
NOTES:					DISTRIBUTION					
(1) Add the static head due to elevation difference (between test point and maximum elevation) to "minimum test pressure at maximum elevation" from PART I.					JOB FILE (AT SPONSORING ORGANIZATION)					
(2) Use lowest pressure on test gauge at any time during test.					GSM&TS RESPONSIBLE DISTRICT SUPERINTENDENT					
(3) Subtract static head due to elevation difference (between test point and maximum elevation) from minimum indicated test pressure.					PROJECT MANAGER/PROJECT ENGINEER					
(4) Subtract static head due to elevation difference (between test point and minimum elevation) from "maximum test pressure at minimum elevation" from PART I.					TECHNICAL & CONSTRUCTION SERVICES - ASSIGNED JOBS ONLY					
(5) Highest pressure on test gauge at any time during test.					CAPITAL ACCOUNTING (FOREMAN'S COPY OF JOB)					
(6) Add static head due to elevation difference (between test point and minimum elevation) to maximum indicated test pressure.					RECORDS SECTION (WC), GSM&TS					
(7) A dead weight tester is only required when testing to a pressure which produces a stress level of 90% of SMYS or greater. However, if a dead weight tester is used on any test, enter the information in the space provided above.					REPORT FAILURES UNDER TEST TO GAS ENGINEERING & PLANNING					

An asterisk (*) indicates values are from the PG&E Technical Guidance Specification for Resolving Unknown Pipeline Features, published 08/01/11.