GENERAL CONSTRUCTION GAS

HYDROSTATIC TEST LOG

Job Number 4164891 Date 4/18/2012

Location: PR-002 Redacted Redacted

PRESSURE RECORDER - 0-2000, S/N 8086JB, 2/3/12
Make, Range and Serial Number of ~~Dead Weight Tester~~ N/A

2/3/2012
Date of Last Calibration

Redacted
Test Supervisor

N/A

Time	~~Dead Weight~~ Pressure	Recorder Pressure	Guage Pressure	Temp.	Remarks
5:00	—	0	0	73	Start 100 lbs TEST/LEAK
5:04		110	110.6	73	Correlated Chart
5:10		110	110.3	73	
5:20		110	110.2	73	
5:30		110	110.0	73	
5:40		110	110.1	73	
5:50		110	110.1	73	
6:00		110	110.0	73	
6:04		110	110.0	73	END 100 lbs TEST/LEAK
7:03 pm			789	73	Start Nitrogen to 790
7:13			763	72	-26
7:23			740	71	-23
7:33			722	71	-28 BLOW DOWN
					LEAK IN STREET

Hydro Test Log.xls