

**Form 1.5 - SCE Planning Area
California Energy Demand 2010-2020 Staff Revised Forecast
Extreme Temperature Peak Demand (MW)**

Year	1-in-2 Temperatures	1-in-5 Temperatures	1-in-10 Temperatures	1-in-20 Temperatures	1-in-5 Multiplier	1-in-10 Multiplier	1-in-20 Multiplier
2009	22,747	24,294	24,749	25,113	1.068	1.088	1.104
2010	22,877	24,433	24,891	25,257	1.068	1.088	1.104
2011	23,181	24,758	25,221	25,592	1.068	1.088	1.104
2012	23,537	25,137	25,608	25,984	1.068	1.088	1.104
2013	23,912	25,538	26,016	26,399	1.068	1.088	1.104
2014	24,218	25,864	26,349	26,736	1.068	1.088	1.104
2015	24,543	26,212	26,703	27,095	1.068	1.088	1.104
2016	24,876	26,567	27,065	27,463	1.068	1.088	1.104
2017	25,226	26,941	27,446	27,850	1.068	1.088	1.104
2018	25,561	27,300	27,811	28,220	1.068	1.088	1.104
2019	25,901	27,663	28,181	28,595	1.068	1.088	1.104
2020	26,267	28,053	28,578	28,999	1.068	1.088	1.104

