

**Form 1.5 - SCE Planning Area
California Energy Demand 2012-2022 Staff Final Forecast
Extreme Temperature Peak Demand**

Year	1-in-2 Temperatures	1-in-5 Multiplier	1-in-5 Temperatures	1-in-10 Multiplier
2011	21,780	1.045	22,761	1.076
2012	21,813	1.045	22,795	1.076
2013	21,892	1.045	22,878	1.076
2014	22,047	1.045	23,039	1.076
2015	22,292	1.045	23,295	1.076
2016	22,630	1.045	23,648	1.076
2017	22,960	1.045	23,994	1.076
2018	23,248	1.045	24,294	1.076
2019	23,502	1.045	24,559	1.076
2020	23,721	1.045	24,789	1.076
2021	23,899	1.045	24,974	1.076
2022	24,056	1.045	25,139	1.076

**ast - Low Demand Case
(MW)**

1-in-10 Temperatures	1-in-20 Multiplier	1-in-20 Temperatures
23,436	1.096	23,871
23,471	1.096	23,907
23,556	1.096	23,994
23,723	1.096	24,164
23,986	1.096	24,432
24,350	1.096	24,802
24,705	1.096	25,165
25,015	1.096	25,479
25,288	1.096	25,758
25,524	1.096	25,999
25,715	1.096	26,193
25,884	1.096	26,365