

**Form 1.5 - SCE Planning Area
California Energy Demand 2012-2022 Staff Final Forec
Extreme Temperature Peak Demand**

Year	1-in-2 Temperatures	1-in-5 Multiplier	1-in-5 Temperatures	1-in-10 Multiplier
2011	21,780	1.045	22,761	1.076
2012	22,340	1.045	23,346	1.076
2013	22,872	1.045	23,901	1.076
2014	23,193	1.045	24,237	1.076
2015	23,484	1.045	24,540	1.076
2016	23,796	1.045	24,866	1.076
2017	24,114	1.045	25,199	1.076
2018	24,427	1.045	25,526	1.076
2019	24,751	1.045	25,865	1.076
2020	25,054	1.045	26,182	1.076
2021	25,337	1.045	26,477	1.076
2022	25,591	1.045	26,742	1.076

**ast - Mid Demand Case
(MW)**

1-in-10 Temperatures	1-in-20 Multiplier	1-in-20 Temperatures
23,436	1.096	23,871
24,038	1.096	24,485
24,610	1.096	25,068
24,956	1.096	25,419
25,268	1.096	25,738
25,604	1.096	26,080
25,947	1.096	26,429
26,284	1.096	26,772
26,632	1.096	27,127
26,958	1.096	27,459
27,262	1.096	27,769
27,536	1.096	28,047