

**Form 1.5 - SCE Planning Area  
California Energy Demand 2012-2022 Staff Final Forecast  
Extreme Temperature Peak Demand**

Year	1-in-2 Temperatures	1-in-5 Multiplier	1-in-5 Temperatures	1-in-10 Multiplier
2011	21,780	1.045	22,761	1.076
2012	22,398	1.045	23,406	1.076
2013	22,904	1.045	23,934	1.076
2014	23,479	1.045	24,536	1.076
2015	23,875	1.045	24,950	1.076
2016	24,255	1.045	25,347	1.076
2017	24,622	1.045	25,730	1.076
2018	25,013	1.045	26,139	1.076
2019	25,442	1.045	26,587	1.076
2020	25,907	1.045	27,072	1.076
2021	26,323	1.045	27,507	1.076
2022	26,739	1.045	27,943	1.076

**ast - High Demand Case  
(MW)**

1-in-10 Temperatures	1-in-20 Multiplier	1-in-20 Temperatures
23,436	1.096	23,871
24,100	1.096	24,548
24,644	1.096	25,102
25,263	1.096	25,733
25,690	1.096	26,167
26,098	1.096	26,584
26,494	1.096	26,986
26,914	1.096	27,414
27,376	1.096	27,885
27,876	1.096	28,394
28,323	1.096	28,850
28,772	1.096	29,306