



# R.12-03-014: Energy Division Workshop – Operating Flexibility Modeling



**Nathaniel Skinner**  
***Senior Analyst, Generation & Transmission Planning***  
**California Public Utilities Commission**

September 19, 2012



# Remote Access

## **WebEx**

Meeting Number: 741 769 312

Meeting Password: LTPP

[https://van.webex.com/van/j.php?  
ED=189577152&UID=491292852&PW=N  
NGQ4MGM0MTBk&RT=MiM0](https://van.webex.com/van/j.php?ED=189577152&UID=491292852&PW=NINGQ4MGM0MTBk&RT=MiM0)

## **Call in #:**


866-758-1675

*Note: \*6 to mute/unmute*

## **Passcode:**

3481442

*Upon entry to the call, please place yourself on mute,  
and remain on mute unless you are asking a question*



# Agenda

Time	Item
10:00 - 10:10	Introduction
10:10 - 10:45	Revisiting the "Step 0" and "Step 1" methodologies
10:45 - 11:15	Review of activities between 2010 LTPP settlement and today
11:15 - 12:15	Review probabilistic methodology for evaluating flexibility
12:15 - 1:10	Lunch
1:10 - 2:00	Should and how can operating flexibility criteria be understood within the context of NERC/WECC standards
2:00 - 2:30	Considering & modeling resources to meet operating flexibility needs
2:30 - 2:45	Break
2:45 - 3:00	Scenarios and Assumptions and informing other processes
3:00 - 3:15	Thoughts on the Flexibility Procurement Modeling Challenge
3:15 - 3:45	Q&A Session
3:45 - 4:00	Wrap-up / Next steps






# Workshop Purpose


- Review past (2010 LTPP) Operating Flexibility modeling approaches
- Examine proposed modeling approaches for the 2012 LTPP
- Begin framing discussion for meeting any needs identified for end of 2013 decision







# Roadmap






? ) 1 □ % 5 2 □ □ - # A 5 5 5 y A 2 % y \* 5  
f( □ R . B 9 - 0 3 - 0 B 4

= % □ R ( □ # 3 1 □ , E A 1 4 u 5 v 1 □ 5 1 4 ( □ , = % □ 1 □ A 2 % y \* 5 % 2 3  
□ 1 v 1 ( ) 0 1 2 □


□ . u 4 . 1 2 □ L 5 u , ' □ 5 2 4 5 % # = % □ 1 □ □ 1 v 1 ( ) 1 □

/ ' U / , , ( □ \* . ( ) □ 1 ) □ 1 0 b 1 □ B 9 , 9 0 B 9





□ 1\*4□5 □5 2 (f' %\* □= 1□ (3 %23 = (31+






$$u3y = 1 ( 3( \text{ } y$$

- V%5/b55y %23 u241 %2 y ( f 121&%b# 1\*( u41\* %23 \text{ } %3 #/11y 3110 51 \*y\* 10 1 u+5 2 %23 \text{ } %3 f( \text{ } &5 1 qu510 12\*
- / u12y, \text{ } %3 5 1 3( 0 5%2 u24( 2 ( #/1 v%5/b#
- 33% R' 5 ( 3u41\* &( %3355 2%u24( 2 ( #/1 v%5/b#\* \text{ } % 5 ) %4 \text{ } %3-f( \text{ } &5 %23 1 u+5 2 1 qu510 12\*
  - Wind, and
  - Solar
- y\* 10 1 u+5 2 %23 \text{ } %3 f( \text{ } &5 1 qu510 12\* 31) 123 ( 2 11 f%4 ( \* :
  - Forecast quality: Load, Wind and Solar forecast errors
  - Interaction between load, wind and solar: net variability
  - Market timeline: how fast the market re-commit and re-dispatch the controllable resources

/ AI? 4. 13u-2' (41\*\*



/ %4u+/%52 □ . ( u □ y † %3-f( † &52 □ □ 1qu510 12 □

- L( %3 □ ( † &52 □ 5 31f5213 % □ 1 35f1 □ 1241 b1 □ &112 □ 1  
5-0 52 f( □ 14% □ 13 21 □ † %3 %23 □ 1 . ( u □ % 1%3 f( □ 14% □ 13  
21 □ † %3
- □ 1 □ 1 □ 0 521 □ 1 95 □ ) 1 □ 412 □ 51 ( f 0 %A5 u0 † %3-f( † &52 □  
□ 1qu510 12 □

$$\Delta G^f = L_{f,5} - G_{f,5} - L_{,} - G_{,}$$







/ %4u+/%52 . ( u y 1 u+/%5 2 1qu510 12

- R1 u+/%5 2 5 31f5213 % 1 35f1 1241 b1 & 112 1 21  
 † %3 6† %3- & 523- \* ( †/% 23 1 5 0 5u1 f( 14% 13 21  
 † %3 6† %3- & 523- \* ( †/%
- 1 1 0 521 1 95 ) 1 412 51 0 %A5 u0 1 u+/%5 2  
 1qu510 12

$$\Delta G = L - G - G - L_{f,5} - G_{f,5} - G_{f,5}$$


□ † & 4. % □ □ f( □ 4% # u † % 5 □ † % 3 - f( † † & 5 □ □ 1 qu 5 10 12 □ \*







R1v51 & ( f %4 5v551\* b1 & 112 90B0  
LT' ' \* 1 10 12 %23 ( 3%y




# A3355 2%+\* 12\* 55v5y %23 %2%oy\* 5 ) 1 f( 0 13 \* 5241 July 90BB

- ' R= A2%oy\* 5 011) 05v1 %2%oy\* 5 ( f' R=
  - A+G% 1\*1v1 0 %05 ( v1 0%13 ' R=
  - A+G% 4%1 ' R= ~9B% 5\* 1%3 ( f 4B%
- 01) B 012\* 55v5y
  - A\*\*1\*\*13 %23 b( u2313 5 ) %4\* ( f f( 04% 01 00( 0\*
  - A\*\*1\*\*13 3 5v1\* ( f f+1A5b+1 0% )
- 5 0 5u01 \* 5 u+%/5 2
  - 05 5%bu0\* 5. 5y 013u413 v5 +%/5 2\* ( b\* 1v13
- R1 05 2%+0 ( 31-5 0 %23 4( ( 035%5 2
  - 10 ) 0(v13 0 ( 31-5 0 ( f 0.1 GHG 5 ) 0(v1\* 0.1 01 05 2%+f( &\*
  - If 2( 05 ) ( 004( 2\* 00%5213 01 05 2%+4( ( 035%5 2 4%2 5 ) 0(v1 %441\*\* 0 f+1A5b+1 01\*( u041\*




? ) 1 % 5 2 % 4 5 1 5 % & 5 . 5 1 4 ( 2 1 A  
( f ; ER / 8 E / / \* % 2 3 % 3 \*





B%<sup>0</sup>/245 Au ( 5y A/ E 5 6BAAL: - y\* 10 4(2 ( +  
 ( )) (\* 1\* f 1qu124y 31v5% 2\*


- BAAL is designed to replace CPS2
- BAAL relaxes area regulation needs
- ACE is allowed to be outside BAAL for up to 30 minutes





/ ( 2 ( + ' 1 f( 0 %241 0 %23%3 4( 1\* 6 ' B: 4( 1\*  
J%2u%y 9009 . ( u . A) 5-90B9

### CPS 1 Scores – January 2009 through April 2012




T. 1 %\* \* 1\*\* 0 12 ( f %b% 245 %u ( 5y 4( 2 ( + ) 1 f( 0 %241 5 b% 13 ( 2 . 11 4( 0 ) ( 212\*

- **Control Performance Standard (CPS1)** - measures the control performance of a BA's by comparing how well its ACE performs in conjunction with the frequency error of the Interconnection
- **Balancing authority Ace Limit (BAAL)** - is a real-time measure of Area Control Area and system frequency which cannot exceed predefined limits for more than 30-minutes
- **Disturbance Control Standard (DCS)** - is the responsibility of the BA following a disturbance to recover its ACE to zero if its ACE just prior to the disturbance was greater than zero or to its pre-disturbance level if ACE was less than zero - within 15 minutes
- **Control Performance Rating**

Pass is when  $CPS1 \geq 100\%$ ;  $BAAL_{L50} \leq 30$  minutes &  $DCS = 100\%$




A ( 4. % 54 = ( 31+f( A2%xyz52  
R%0 ) 52 / % 45y uff5451 24y




A \* (4. % 54 0 (31+5 211313 ( %\*1\*\* 1 ) ( b%b55y  
 ( f u) &%3 %0 ) 5 4% %45y \* uff545 24y.

- A 31 1 0 55 54 ) ( 3u4 5 2 \* 5 u+/% 5 2 4% 1 %3( ) \* ( 2y  
 ( 21 ( f 1 0 %2y ) ( \*\* 5+ 4( 0 b52%5 2\* ( f 5) u  
 %\* u0 ) 5 2\*
- A \* (4. % 54 0 (31+4%2 1v%u%1 v%5 u\* 5) u  
 4( 0 b52%5 2\* b% 13 ( 2 ) ( b%b55y 35 5u5 2\* ( f 1  
 \* (4. % 54 5) u v%5/b+\*
- = ( 2 1 / % ( \* 5 u+/% 5 2 31 1 0 521\* 5\* uff545 2 %0 ) 5  
 4% %45y ) ( b%b55y
- I 4( 0 ) +10 12 \* 1 31 1 0 525 54 ) ( 3u4 5 2 \* 5 u+/% 5 2

Av%5%b-1 □%0 ) 5□4% %45y 31) 123\* ( 2 □. 1 b%°/241 ( f  
 \* u) ) y %23 310 %23.



U241 □ % 5 5 \* 5 \* u ) ) + y % 23 310 % 23 % ff14 □ % v % 5 % b 55 y  
( f □ % ) 5 □ 4 % % 45 y.




Av%5%b+1 □%0 ) 5□4% □45y ( f 1%4. □121□%5 2 u25□5  
31□1□0 5213 b% 13 ( 2 □ 1 f( +&5□f%4( □\*:

- = %A5 u0 %23 0 55 u0 4% □45y
- U25□%v%5%b55y 63u1 □( f( □413 %23 0 %52□12%241 ( u□%□1\*:
- □5\*) %4. +1v1+
- R%0 ) □%1
- R%0 ) □5 1 %+&13 6B0 ( □90 0 5u□1\*:



R%0 ) 5 4% %45y \* . ( %1 0 %y ( 44u 3u1 ( v%5/3 2\* 5 b( %v%5/b55y %23 1qu510 12.



T. 5 \* (4. % 54 0 (31+4( 2\* 51\* u241 □%52 51\* 52\*( 0 1  
 (f □ 1 - 1y 52) u□\*, 54+u352□:

- L( %3 f( □14% □
- I2□□. ( u□( %3 □%0 )
- R1qu510 12□\* f( □□1 □u+/%5 2-u) %23 ( %3 f( +( &52 □-u)
- G121□%5 2 by &523, \*( +/%, %23 . y3□( □1\*( u□41\*
- Av%5%b55y ( f □121□%5 2 u25\* 63u1 □( f( □413 %23  
 0 %52 □12%241 ( u□%□1\*:


A 0 ( 31+5 31v1€ ) 13 f( □%□ 1 ) 1 □ 3 □ & . □ . %  
 . ( u□ . % 1 \* □ 5%□ 4( 235□ 2\* .

- ; ( u25□ 4( 0 0 50 12□
- ; ( 4. □ ( 2( € □ 4( 2\* □ □%□ 6\* u4. % 0 □ □ 2 □ □ 1 % 23 0 □  
3( & 2 □ □ 1, 1 □ .:
- 1231) 12312□ & 5. □ 512□ □% ) □ ( b%□ 55y 35 □ □ u□ □ 2  
fu24□ □ 2\* f( □ 1% . . ( u□ □ □ 1 ) 1 □ □ 3
- 12\* uff□ 512□ □% ) □ □ 4% □ % 45y ) □ ( b%□ 55y f( □ 1% . . ( u□  
31□ 1 □ 0 □ 513 □ □ ( u□ . = ( 2□ 1 / % □ € \* □ □ u□ □ % □ 2\*
- 12\* uff□ 512□ □% ) □ □ 4% □ % 45y ) □ ( b%□ 55y f( □ □ 1 & . ( □  
y1% □ 4% □ □ u□ □ % □ 13 b% □ 13 ( 2 B □ 5( 0 □ □ 35 □ □ u□ □ 2

' ( b%b55y 35 □□5u□5 2\* %□ 31v1( ) 13 b%\* 13 ( 2 3%□%  
f( 0 □ 1 ' #A( \* ) □ ( 3u4□5 2 \* 5 u+□%□ 2 0 ( 31+

- H( u□y ( %3 f( □14% □
- H( u□y □1□u+□%□ 2 %23 ( %3 f( # &5□-u) □1qu510 12□
- H( u□y &523, \*( +□, %23 . y3□( □121□%□ 2
- U25( □0 35 □□5u□5 2 fu24□5 2\* b%\* 13 ( 2 f( □413 %23  
0 %5□12%241 ( u□%□1 □%□1\* ( f 1%4. □121□%□ 2 u25□


$121 \square. (u \square \text{ ‰ } \square \% ) \text{ ‰ } 4 \% \text{ ‰ } u \text{ ‰ } \square 13 \text{ ‰ } b \% \text{ ‰ } 13 (2. (u \square y$   
 $\text{ ‰ } \text{ ‰ } \text{ ‰ } f( \square 14 \% \square$




- Upward direction only
- A new stochastic variable
- Met by 60-min ramping capability
- A part of load

$$Inter\text{-}HourRamp_t = \max(0, Load_t - Load_{t-1})$$



T. 1\*1 %1 1A%0 ) +\* ( f ) ( b%b55y 35 □ 5u 5 2  
 fu24 5 2\* ( f \* □ 4. % 54 v%5/b-1\* .



EA f 5 □ □ 1 ) ( b%b55y ( . %v1  
 f % 5 . 5 . 1 □ □ %2 B-5-9 f( 14% □





EA%0 ) +1\* ( f ) ( b%b55y 35 (bu \$ 2 fu24 \$ 2\* ( f  
 \* ( 4. % \$ v% \$ / b +1\* . 64( 2 .





EA% ) +1\* ( f ) ( b%b55y 35 (bu 5 2 fu24 5 2\* ( f  
 \* ( 4. % 5 v%5/b+1\* . 64( 2 .



1 ( 1 2\* % ( 2 1 \* ( 4. % 5 v% 5/b +1\* % 1  
 12f( 413.

	L( 3	L( 3 R0 )	, 53 G12	( + G12	Hy3( (G12	R1U	L U
L( 3	B	0.9774	-0.0947	-0.B997	0.4309	0.370B	0.0799
L( 3 R0 )	0.9774	B	-0.3779	0.6B56	0.0779	0.9064	-0.3B93
, 53	-0.0947	-0.3779	B	-0.B6B7	0.9755	-0.0B07	0.0609
( +	-0.B997	0.6B56	-0.B6B7	B	0.0954	-0.BB0B	-0.5064
Hy3( (	0.4309	0.0779	0.9755	0.0954	B	0.3094	-0.B973
R1U	0.370B	0.9064	-0.0B07	-0.BB0B	0.3094	B	0.B4B5
L U	0.0799	-0.3B93	0.0609	-0.5064	-0.B973	0.B4B5	B

T. 5 5 %2 1A% ) + ( f 1 4( 1 2 0 % 5

G121 2 u25\* 52 1 \* (4. % 54 0 (31+. %v1 1  
 f( + & 52 4. % %4 1 5 54\* f( 0 1 ' +A( \* 0 (31+

- (0 52) u 3% %
  - = %A5 u0 %23 0 550 u0 4% %45y
  - R%0 ) %1
  - ( 413 ( u% 1 %23 0 %52 12%241 ( u% 1 %1\*
- (0 \* 50 u+ %5 2 1\* u+\*
  - Av1 % 1 121 %5 2 4( \* 6( 31 1 0 521 %2 555/+35 ) %4. ( 31

G121 2 u25 5 5 \* ( 4. % 31 0 213  
2 1%. 51 2 ( f 1 = ( 2 / % \* 5 u 2\*.

- ( 413 %23 0 %2 12%241 ( u 1\* %1 31 0 213  
231) 12312 y f( 1%. 121 2 u25
- E%. ( f 1 ( u 1\* 5 31 0 213 b% 13 ( 2 1 u25\*  
( u 1 %1 %23 %3 %& u\* 2 % u25( 0 35 5 u 2  
fu24 2
- A 0 %2 12%241 ( u 1 % 4% 2 f% ( 5 u\* 13 ( 1)  
1\* 12\* 1% ( 2% ) % 1 2 ( f 0 %2 12%241 \*4. 13u 1\*
- A u25 5 u2% 5% b 1 &. 12 %2y ( 21 ( f 1 ( u 1\* ( 44u \*

$$/ ( 2 \times u_i \times 2^* ( f \% 121 \% 2 u25 ( 121 y \% 23$$

$$\% 0 ) \times 4 \% 45 y \% 1 * ubj14 ( :$$

- $$B0-0 \times u_i \times \% 3 \% 0 ) \times 4 \% 45 y 4 ( 2^* \% 5$$

$$AS_i \leq 0 \times RampRate_i, MaxCap_i - MinCap_i$$
- $$90-0 \times u_i \times \% 3 \% 0 ) \times 4 \% 45 y 4 ( 2^* \% 5$$

$$AS_i + LFU_i \leq \min(20 \times RampRate_i, MaxCap_i - MinCap_i)$$
- $$60-0 \times u_i \times \% 3 \% 0 ) \times 4 \% 45 y 4 ( 2^* \% 5$$

$$AS_i + LFU_i + LdRamp_i \leq \min(60 \times RampRate_i, MaxCap_i - MinCap_i)$$
- $$= \% 5 u0 4 \% 45 y 4 ( 2^* \% 5$$

$$E_i + AS_i + LFU_i + LdRamp_i \leq MaxCap_i$$

$E_i$  - energy dispatch                       $A_i$  - total upward ancillary service contribution  
 $L_i U_i$  - load following up contribution     $L_i R_i$  - inter-hour load ramp



T. 1 0 ( 31+\* 11- \* %4% -4( \* □\*( t 5 2 □ ( 0 11 □121 □□y  
%23 %4 □0 ) 5 □ 4% ) %45y □ 1qu510 12 □\*.


- G121 □%5 2 u25\* %1 35 ) %4. 13 14( 2( 0 54%□y □ ( 0 11 □  
₣ %3 f5\* □
- R10 %52 □ qu%5513 □%0 ) 5 □ 4% ) %45y 5 u\* 13 □ ( 0 11 □  
u) &%3 %245□%y \* 1 □v51, ₣ %3 f( ₣ &5 □, %23 5 □1 □. ( u □  
₣ %3 □%0 ) □ 1qu510 12 □
- E21 □□y 35 ) %4. %23 □%0 ) 5 □ 4% ) %45y 4( 2 □□5u5 2\* %1  
4( -( ) 5 513 &. 12 □ 1 □ 5 5\* uff512 □□%0 ) 5 □ 4% ) %45y  
525□/□y



$= (21 / \% \text{€} * 50 u \text{+} \% 5 2 31 \square 1 \square 0 521 * 52 * \text{uff} 54512 \square \square \% ) 52 \square$   
 $4\% \text{) \%} 45y ) \square ( b \% b 55y .$


- $= (21 / \% \text{€} * 50 u \text{+} \% 5 2 5 4( 23u4 \square 13 u * 52 \square \square 5$   
 $* \square ( 4. \% 54 0 ( 31+$
- $12 * \text{uff} 54512 \square \square \% ) 52 \square 4\% \text{) \%} 45y \square 1 * u \text{+} * \% 1 ) \square 1 * 12 \square 13 52 \%$   
 $) \square ( b \% b 55y 35 \square \square 5u \square 5 2 f( \square 0 \% \square$
- $T. 1 - 1y \square 1 * u \text{+} * \% 1 \square 1 ) \square ( b \% b 55y \square ( . \% v 1 \square \% ) 52 \square$   
 $4\% \text{) \%} 45y * . ( \square \square \% \square 1 1 \% 4. . ( u \square \% 23 \square 1 ) \square ( b \% b 55y$   
 $35 \square \square 5u \square 5 2 ( f \square 1 v( \text{t} 0 1 ( f \square 1 * . ( \square \square \% \square 1 *$

T. 5 1A%0 ) +1 . % %0.7% ) ( b%b55y ( . %v1 90-0 52  
 □%0 ) 52 □ 4% ) %45y \* . ( □□%□1 1%4. . ( u□





R1\*u+\* f( □□.1 □u) 1□' 1% ) 1 5 3.

T. 1 . 5 . 1\* □ 90-0 □ % ) □ 4% %45y \* . ( □ % □ 1 5 4,66B  
 = , □ 5 1A% ) +.



R1\*u+\* f( □ □ 1 □ u ) 1□' 1% ) 1 □ 3.

T. 1 ) ( b%b55y ( . %v1 B0-0 2 □% ) 2 □ 4% %45y  
 \* . ( □%□1 1%4. . ( u□5 0.B%.



R1\*u+\* f( □□1 □u) 1□' 1% ) 1□3.

= (21 / % \* 50 u + % 2 1 \* u + \* f( % #) 1 3 \* % 1  
 \* u 0 0 % 5 13 % f( # & \* :

	Example Case			
	Super- Peak		Summer Off- Peak	
	10- min	20- min	10- min	20- min
# of Hours in the Period	2298	2298	2298	2298
Probability of Shortage	0.12%	0.78%	0.04%	0.16%
Max Shortage (MW)	1,180	4,661	1,420	3,855



EA) 14 13 2u0 b1 (f . (u\* &5. %0 ) 5 4% %45y  
 \* . ( %1 5 9090 %1 4%4u+-%13 b%\* 13 ( 2 . 1  
 ) ( b%b555) \* .

Example Case	
10- min	20- min
1.68	8.59

1 5 2\* uff452 %0 ) 5 4% %45y 1A) 14 %5 2.



, . %&1 #1%213 f( ( 0 . 5 % ) ( ( %4. :

- I3( 1\*

- U\* 1 ) ( ( b%b55y 35 u5 2\* ( ( 4% u1 u241 %2 51\* 5 - 1y 5) u f%4 ( ( \*
- IO ) #0 12 % ) 5 4( 2\* %2 \* %23 f#A55y 1qu510 12 \*
- ' 1\* 12 2\* uff55 2 % ) 5 4% %45y 1v12 \* 5 ) ( ( b%b55 54 f( ( 0 %

- I3( 1\* 2( (

- 1431 u25 4( 0 0 50 12
- IO ) ( \* 1 4. ( ( 2( ( 5%+4( 2\* %2 \*


- I4%2 b1 5 ) ( ( v13 (

- U\* 1 0 u+5y1% \* y24. ( ( 25 13 . 5 ( ( 5%+3%% ( ( 4% u1 0 ( ( 1 v%5/5 2\* ( f 5) u\* ( ( 4. % 54 v%5/b#1\*



California ISO  
Shaping a Renewed Future

A 3y (u) ( = 11 5  
A\*\* 10 by B5+6AB: B3B7



' #A( \* \* 50 u+%/5 2\* %1 4( 23u4 13 %b( u ) 1 f( 0 %241  
( f † 4%+4% ) %45y 1qu510 12 1\*( u41\* 5 9090.

- B% 1 0 ( 31 † H5 . -L( %3 \* 412%5 5 90BB LT' ' \* 03y  
– R13u413 0 5 02 5 1 ( f\*( 0 1 310 %23 1\*( ) ( 2\*1 1\*( u41\*  
f( 0 4 ( B. ( u
- L/ R 1\*( u41\*  
– A3313 3,B73 = , † 4%+4% ) %45y 1qu510 12 L/ R: 1\*( u41\*
- A \* 12\* 555y 4% 1  
– R13u413 4% ) %45y ( f 1v12 -b% 13 310 %23 1\*( ) ( 2\*1 1\*( u41\*

L/ R □ 1\* ( u □ 41\* % □ 1 % □ 313 ( □ □ / E % 23 □ □ G&E z ( 21\* .

- 3,B73 = , L/ R □ 1\* ( u □ 41\* b % 13 ( 2 □ 1 I □ ? ? T / \* □ u3y
  - L ( \* A2 □ 1 □ 4 \* B % 5 : 9,370 = ,
  - B5 □ / □ 11- V12 □ u □ % □ % □ 1 % : 430 = ,
  - □ % 2 □ 5 □ ( : 373 = , \*



- L/ R □ 1\* ( u □ 41\* % □ 313 % \* % 4 ( 0 b 5 % 5 2 ( f / / GT % 23  
GT u25\*
  - □ / E : 9 A 500 = , / / GT u25\*
  - □ / E : B7 A B00 = , L = □ B00 GT u25\*
  - □ □ G&E : B A 373 = , / / GT u25□

\* I □ % \* u 0 1 \* □ % □ % 2 □ 5 □ ( ) ( ) ( \* 13 □ 121 % 5 2 5 5 4 u 313 % 1 % 3 y . □ ( □ 1 ( □ % 2113 5  
 □ % 2 □ 5 □ ( \* . ( u 6 b 1 373 = , ) □ \*  
 ' 5 ' 5 ( = 300 = , Qu % 5 B u \* . = B00 = , E \* 4 ( 23 5 ( E 21 □ □ y / 12 □ 1 □ = 45 = ,

L/ R 1\*(u 41\* . %v1 □121 54 ( ) 1 □%52 □ 4. %□4 □ 5 54\*  
 4( 0 ) %□%b#1 □ ( 21&1 □1A552 □ □1\*( u 41\* . \*

Resource	Max/Min Capacity (MW)	Full-Load Heat Rate (Btu/kWh)	Ramp Rate (MW/min)	Forced Outage Rate (%)	Maintenance Rate (%)	Start-up Time (hour)	Start-up Cost (\$)
SCE NEW GT	100/40	9,191	12.0	7.24	10.0		1,200
SCE NEW CCGT	500/200	7,000	7.5	4.96	10.0	2	44,520
SDGE NEW CCGT	373/200	7,000	7.5	4.96	10.0	2	44,520
Gateway (CCGT)	530/265	7,000	10.0	10.00	10.0	2	24,411
Sentinel (GT)	106/43	9,191	12.0	10.00	10.0		1,000

\* □ ( 1413 ( u □%1 □%1\* ( f □1  
 21& □1\*( u □41\* □%1 b%13 ( 2  
 ; ER/ GA □ □ 9006-90B0  
 %v1 □%1 E □? R3, / / GT f ( □  
 %□# = , \* □51\* □%23 GT f ( □50  
 ) □#\* = ,



L/ R □ 1\*( u □ 41\* . % & 1 . 5 . 4% % 45y f% 4 ( □ \* % 23  
 4( 2 □ □ 5u □ 5 2\* □ ( % 245% % y \* 1 □ v 541\* % 23 † % 3 f( † & 52 □

### Monthly Capacity Factors

Resource	1	2	3	4	5	6	7	8	9	10	11	12	Annual
SCE □ □ η NEW	9.5	11.2	10.0	9.8	12.0	16.5	20.3	17.9	7.9	10.0	8.0	10.2	11.9
SCE □ □ η NEW	53.1	60.0	61.4	64.2	59.4	64.1	73.7	83.4	80.9	66.9	61.1	68.3	66.4
SDGE □ □ η NEW	49.2	62.1	55.9	20.4	72.6	76.5	69.0	87.4	83.7	50.9	37.8	20.3	57.1
Gateway □ □ η (C)	52.0	45.6	55.3	48.7	45.5	56.1	62.8	55.2	60.1	56.2	60.3	60.7	54.9
Sentinel □ □ η (C)	22.1	20.3	17.2	18.3	21.1	19.6	20.4	19.1	11.6	16.2	16.0	12.1	17.8
GT □ □ η Average	10.9	10.7	8.0	10.8	10.9	12.0	11.2	9.5	6.6	8.4	9.3	10.4	9.8
CCGT □ □ η Average	48.5	45.9	40.6	39.8	36.1	40.2	62.0	65.4	55.1	51.0	49.6	51.9	49.4

### Ancillary Service and Load Following Contribution (GWh)

Resource	LF	LF	Non-Spin	Reg-D	Reg-U	Spin
SCE □ □ η NEW	23.9	537.3	1.9	32.1	320.0	914.8
SCE □ □ η NEW	1,888.0	849.2	0.5	101.8	11.6	577.2
SDGE □ □ η NEW	264.9	217.8	0.0	202.7	78.6	56.4

L/ R 1\*(u41\* %1 . 5. y u55z13.

- EA%0 ) #1 - u55z%5 2 ( f □/ E ; E, // GT 1\*(u41
  - = %A4% %45y: B,000 = , @ A500 = , :
  - T( %+) ( \*\* 5#1 □121□%5 2 5 9090: 7,774 AB,000 = 7,774 G, .
  - A22u%+4% %45y f%4( □ 66.40% 65,733 G, . □121□%5 2:
  - U) &%3 A□ %23 † %3 f( † &5□ 4( 2□5u5 2: B,439 G, .
  - G121□%5 2 ) †\* A□ %23 L□ 4( 2□5u5 2: 7,97B G, .
  - T( %+u55z%5 2 □%1: 79.77%
  - □( □413 %23 0 %5 12%241 ( u□%□1 □%1: B4.96%
  - U2u55z13 4% %45y: 9.96%



A3355 2%+f+1A5+1 4% %45y 5 211313 2 %3355 2 ( □ 1  
 L/ R □1\*(u□41\*.

- U) ( B,95B = , 90-0 2 □% ) 2 □ 4% %45y \* . ( □%□1  
 512 5513
- / ( 2\* 5 □12 □&5. □ 1 f232 □\* 2 ) □1v5 u\* \* □u3y
  - ; 113 f( □4,600 = , L= □B00 GT 4% %45y &5. z1□ ( u□%□1  
 512 5513 2 ) □1v5 u\* \* □u3y
  - 3,B73 = , L/ R 4% %45y %3313
  - B,95B = , □1\* 5u%+\* . ( □%□1
  - A3355 2%+310 %23 □1\* ) ( 2\*1 u\*%□1 f( 0 □13u413 0 25 u0 □u2  
 5 1

12 1 \* 12\* 55/5y 4%\* 1 1v12-b%\* 13 310 %23 1\*) (2\*1  
 4% 45y 5 13u413 by 40.7%.\*

Region	Original DR Capacity (MW)	Reduced DR Capacity (MW)	Reduction (MW)
PG&E	1,687	732	955
SCE	2,827	1,977	850
SDGE	302	146	156
<b>TOTAL</b>	<b>4,816</b>	<b>2,855</b>	<b>1,961</b>

\* E21 y u\*%1 5\* f( 1 310 %23 1\*) (2\*1 1\*( u41\* %1 2( 13u413 \*( \*(0 1 (f 1  
 1\*( u41\* 0 %y b1 31) y13 f( 0 ( 1 . (u\*

□10 %23 □1\*) (2\*1 □1\* (u□41\* %1 u\* 13 f□1qu12□y 52  
 \* u0 0 1□0 (2□\*.

### Number of Hours DR Resources Deployed


Case	Jul	Aug	Sep	Oct	Sum
Original 웹□ηDR 웹□ηCapacity	44	22	3	2	71
Reduced 웹□ηDR 웹□ηCapacity	47	23	2	2	74

R%0 ) 5 4% %45y \* . ( %1 541%\* 1\* &5. 13u45 2 ( f  
310 %23 1\* ) ( 2\* 1 4% %45y.

- U 55%5 2 ( f L/ R 1\* ( u 41\* \* . ( &\* \* 0 %4. %2 1\*
- 90-0 5 %0 ) 5 4% %45y \* . ( %1 5 541%\* 13 f ( 0  
B,95B = , ( 3,9B9 = ,  
– B,96B = , 541%\* 1 5 \* . ( %1 &5. B,96B = , 13u45 2 5  
310 %23 1\* ) ( 2\* 1 4% %45y
- 10 %23 1\* ) ( 2\* 1 4% %45y 5 “f+A5+A”  
– ; ( %0 ) %1 4( 2\* %5  
– ; ( 35 ) %4. %b+A 60 5 4% %45y = 0 %A4% %45y:  
– 115 u) f+A5+A 35 ) %4. %b+A 4% %45y ( 241 31) † y13



= 1 ( 3 ( 5 \* f ( ; 1A . %\* 1 ( f  
u3y



T.  $\square 11 0 1 \square ( 3( \text{f} \square 51^* \& 1 \square u^* 13 \text{f} \square 1 ) \square 1 v \text{f} u^* ). \% 1$   
 $( f^* \square u 3y.$

- '  $\square ( 3u4 \text{f} 2 4( * \square^* \text{f} u \text{f} \% \text{f} 2$ 
  - $\square 1 \square \text{f}, 4. \square ( 2( \text{f} \square 51 \% \text{f}, u 25 \square 4( 0 0 50 12 \square, \text{f} \square 1 \text{A} \square 55y 4( 2^* \square \square \% \square 2 \square^*$
  - $\square \text{f} \&, 31 \square 1 \square 0 \text{f} \text{f} \square \text{f}$
  
- $L( ** ( f L( \% 3 ' \square ( b \% b 55y \text{f} L? L' : 4 \% 4 u \text{f} \% \text{f} 2$ 
  - '  $\square ( b \% b 55 \square \text{f}, \text{f} \% \square, 0 u + 5y 1 \% \square. \text{f} \square ( \square 51 \% \text{f} 3 \% \% ) \square ( b \% b 55 \square \text{f} ( u \square ) u \square^*$
  - ;  $( \text{f} \square 1 \text{A} \square 55y 4( 2^* \square \square \% \square 2 \square, 2( 2-4. \square ( 2( \text{f} \square 51 \% \text{f}$
  
- $\square \square ( 4. \% \square \text{f} * \text{f} \text{f} u \text{f} \% \text{f} 2 0 ( 31 \text{f} \square$ 
  - $\square \square ( 4. \% \square \text{f}, \text{f} \% \square, \text{f} \square 1 \text{A} \square 55y 4( 2^* \square \square \% \square 2 \square^*, ) \square ( b \% b 55 \square \text{f} ( u \square ) u \square^*$
  - ;  $( 2-4. \square ( 2( \text{f} \square 51 \% \text{f}, 2( u 25 \square 4( 0 0 50 12 \square, * \text{f} \square \square 1-y 1 \% \square 3 \% \% \square$

T. 1 0 1 ( 3( † 51\* f( □. 1 21A□). %\* 1 ( f\* u3y\*. ( uθ  
b1 %b† □:

- U\* 1 \* ( 4. % 54 0 ( 31-2 □ % ) ( %4. ( 4% □ u□  
u241 □ %2 51\* 2 - 1y 2) u□v%5/b†\*
  - L( %3, □121&%b† %23 . y3( □121□%5 2, f†A55y □1qu510 12□\*,  
□1\*( u□41 %v%5/b55y, 1□4.
- E2f( □41 ( ) 1□%5 2%†4( 2\* □□%2□\*
  - / . ( 2( † □54%†-2- %□1\* b1&112 2□1v%†
  - R%0) 2□4( 2\* □□%2□\* %23 f†A55y □1qu510 12□\*



T. 1 0 1 ( 3( † 5 \* f( 1 21A ). %\* 1 ( f \* u3y \* . ( u-  
b1 %b-1 ( : 64( 2 :

- I312 5y 4% %45y %23 f-1A555y \* . ( %1\*
  - 5f1 12 5%2 4% %45y \* . ( %1\* f( 0 f-1A555y \* . ( %1\*
  - 51 ) 1 5 5 1 0 \* ( f ( ) 1 %5 2%† ) 1 f( 0 %241 \* %23%3\*  
6BAAL, / ' B, 14.:
- ' ( ) ( \* 1 \* ( † 5 2\* ( 0 11 1 ) 1 f( 0 %241 \* %23%3\*
  - Qu%2 5y 5 5 1 0 ( f 4% %b555 \* 2( 14. 2( † 5 \*
- H%v1 0 %2%1%b-1 4%4u+%5 28 5 u+%5 2 5 1



# Scenarios and Assumptions



**Nathaniel Skinner**

***Senior Analyst, Generation & Transmission Planning***  
**California Public Utilities Commission**

September 19, 2012





# Scenarios Purpose

- Inform policy-makers by providing information on a broad range of plausible future scenarios
- Inform bundled procurement plans and positions
- Inform the transmission planning process and analysis of operating flexibility
- Limit the range of analysis to conform with resource constraints, while meeting policy objectives for the current LTPP

63






# Problem Statement

Scenarios should be developed to answer the following primary questions:

- What new infrastructure needs to be constructed to ensure adequate reliability?
- What mix of infrastructure minimizes cost to customers over the planning horizon?





# Planning Area & Period

- CAISO controlled transmission grid & distribution systems
- Period 1 – 10 years ahead
  - T(3%y □ □(u□. 9099
- Period 2 – 20+ years ahead
  - 2023 through 2034
  - Simplified analysis to understand impacts of choices made to meet Period 1 needs





# Example Scenario: 1 - Base

- Reflect expectations of the future with little change from existing policies
- Key Assumptions:
  - Mid load, mid inc. EE, mid small PV, low CHP
  - Mid DR, high probability additions, commercial RPS
  - Retirements: Low nuclear, low hydro/wind/solar, mid other

**How to get there:** No change to business as usual and programs achieve results consistent with forecast expectations







Energy+Environmental Economics

# Thoughts on the Flexibility Procurement Modeling Challenge

CPUC Workshop  
9/19/2012

Arne Olson, E3 Partner



# Agenda

- + What Question Are We Trying to Answer?**
- + What Tools Are Available Today?**
- + What Would a Hybrid Model Look Like?**







Energy+Environmental Economics

# What Question Are We Trying to Answer?



# Today's Planning Problem Has Two Related Questions

- 1□ How many MW of dispatchable resources do we need to (a) meet load, and (b) meet ramping requirements on various time scales?
- 2□ What is the optimal mix of new resources, given the characteristics of the existing fleet?





# Answer is a Matter of Matching Demand and Supply

## + Demand is a function of a number of variables:

- Load
- Load forecast error
- Load variability
- Expected renewable production
- Expected renewable production forecast error
- Expected renewable production variability


## + Supply is the ability of the fleet of dispatchable resources to respond on the appropriate time scale



# Problem is Stochastic in Nature

## + Load is stochastic, variable and uncertain

- Often characterized as "1-in-5" or "1-in-10"
- Subject to forecast error



## + Renewable output is also stochastic, variable and uncertain

## + Supplies can also be stochastic

- Hydro endowment varies from year to year
- Generator forced outages are random

## + Need to know size, probability and duration of any shortfalls







# Stochastic Modeling Must be Robust

## + Need will occur during "tail" events for both demand and supply

- Need enough iterations to accurately capture low-probability events

## + Flexibility need shortages will be related to capacity shortages

- Inflexible capacity can be a substitute for flexible capacity under some circumstances






# Need Must Be Defined on a Number of Time Scales

## + Peak Load is an annual phenomenon

- Loss of Load can occur in 50-250 hours per year
- Typically measured on an hourly basis

## + Ramping needs must be defined over much smaller time increments

- 5 hours
- 1 hour
- 20 minutes
- 5 minutes
- 1 minute





Energy+Environmental Economics

# What Tools are Available Today?





# Planning Models

## + Calculate Loss-of-Load Probability (LOLP) and related metrics to determine the probability that resources will be inadequate to meet peak loads


- Conducted to support calculation of a reserve margin or to determine least-cost expansion plan

## + Advantages

- Stochastic model that considers the full range of load conditions

## + Limitations

- Ignores operations
  - In the past, planning to prevent loss of load has provided enough flexibility







# Operations Models

## + **Production simulation models minimize operating costs subject to constraints on unit availability, transmission availability, etc.**

- Conducted to determine the total cost associated with meeting electric load over 8760 hours

## + **Benefits**

- Treats details of generator operating limitations, transmission, and time-sequential behavior

## + **Limitations**

- Deterministic
- Significant unnecessary detail
- Lengthy run time






# Enhanced Planning Models

+ **E3's LOLP/ELCC Model incorporates reserves into LOLP framework**

+ **Does not treat flexibility characteristics explicitly**

- Flexibility need modeled as fixed hourly parameter
- Does not measure ability of fleet to meet flexibility needs
- Requires reference to a portfolio that is assumed to be sufficiently flexible (All-Gas Case)

**E3 LOLP Model Flow Chart**





Energy+Environmental Economics

# What Would a “Hybrid” Model Look Like?






# Planning for Reliable Operations

## + A model is needed that plans for reliable system operations, satisfying:

- Capacity Requirement – according to traditional metrics for capacity planning
- Flexibility Requirement – accounting for the limitations of the fleet in time sequential operations

## + Measures taken to meet need in one category may satisfy need in the other

- The model should select the least-cost array of portfolio/operational changes to meet flexibility
- Differentiated value of resource types over different time scales should be captured
  - Storage provides fast response ramping over short time periods, CCGTs provide capacity and ramp, etc.






# Flexibility Requirement – Defining new set of metrics

## + Attempts to quantify unit flexibility (NERC's IVGTF Task 1.4)

' (&1□R1-8/55y = 1□51\*:

R%0 ) R1-8/55y = 1□51\*:\*



## + Still unanswered: How could these metrics be used in a procurement process?


- How would standards be determined and adopted?
- Is there a way to compare flexibility with adequacy using a common currency?



# Best solution to satisfy need

## + Two options to mitigate flexibility violations:

### Flip a switch



#### + Operational changes can mitigate flexibility shortfalls

- Reserve scheduling, "pre-curtailment" of renewables

### Grab a shovel

#### + Steel in the ground can help to meet both capacity and flexibility requirements

- Fast, expensive resources vs. cheaper, slower ones



## + A useful model will be able to quantify the trade-offs between these options

- What measure or combination of measures satisfies need?



# The “Sledgehammer” Approach: Stochastic Production Simulation

- + **Minutely time step resolution**
- + **Monte Carlo for forecast errors**
- + **Requires large datasets**
  - Detailed load, wind, solar datasets
  - Individual unit specifications
  - Scheduled and forced outages
  - Hydro and import conditions



## Challenges

- + **Run time: full stochastic simulation may be impractical**
- + **Year-long simulation does not capture long-term uncertainties, important for planning analysis**
- + **Flexibility of system depends on chosen reserve requirements – possibility of “false violation”**
- + **Difficult to incorporate expansion decision**



# One Path Forward: Reduced-Form Production Simulation Modeling

## + Three key modifications to production simulation modeling framework:

1  **Stochastic operations:** Run thousands of draws of a single day per month to accurately characterize long-term uncertainty

- Preserve time-sequential unit commitment and operations over 24 hours

2  **Endogenous reserves:** Include endogenous, minutely specification of reserve flexibility requirements to avoid false violations and accurately characterize fast-ramping resource

3  **Expansion decisions:** Incorporate operational and expansion decisions (with fixed costs) to find optimal solutions

+ **Requires elimination of *all* detail that doesn't help answer question at hand in order to minimize run time (e.g., transmission)**







Energy + Environmental Economics

# Thank You!

Energy and Environmental Economics, Inc. (E3)

101 Montgomery Street, Suite 1600

San Francisco, CA 94104

Tel 415-391-5100

Web <http://www.ethree.com>

Arne Olson, Partner ([arne@ethree.com](mailto:arne@ethree.com))



# Wrap Up & Next Steps



**Nathaniel Skinner & Noushin Ketabi**  
***Senior Analysts, Generation & Transmission Planning***  
**California Public Utilities Commission**

September 19, 2012






# Operating Flexibility #3

- Planning for an early November third workshop
  - Would explore the path forward for operating flexibility analyses and interpreting these needs into the LTPP
  - In person or fully over WebEx?





# Calendar

## September

**19: Track II Final Scenarios to be sent to service list**

**24: Track I Briefs Due**

## October

**5: Track II Final Scenarios Comments Due**


**LTPP/Energy Storage Workshop Comments Due**

**12: Track I Reply Briefs Due**

**19: Track II Final Scenarios Reply Comments Due**

**LTPP/Energy Storage Workshop Reply Comments Due**





# Calendar

## November

**2: Track III Rules Comments Due [PENDING ALJ RULING]**

**20: Track II Scenarios PD**

## December

**12: Track I PD**


**20: Track II Scenarios Decision on Agenda**

## January

**TBD Commission Meeting: Track I Decision on Agenda**







**Thank you!**  
**For Additional Information:**  
**[www.cpuc.ca.gov](http://www.cpuc.ca.gov)**  
**[www.GoSolarCalifornia.ca.gov](http://www.GoSolarCalifornia.ca.gov)**  
**[www.CalPhoneInfo.com](http://www.CalPhoneInfo.com)**

