

From: Allen, Meredith
Sent: 12/27/2012 12:58:32 PM
To: 'Fugere, Raymond G.' (raymond.fugere@cpuc.ca.gov)
Cc:
Bcc:
Subject: RE: NERC Alert Advice Letters

Mr. Fugere,

Attached are the tables. The reason that the new clearances will be higher than the minimum clearances is that there are standard tower extension heights for each type of structure.

Please let me know if you need additional information.

Thanks,

Meredith Allen

415-828-5765 (cell)

From: Allen, Meredith
Sent: Thursday, December 27, 2012 12:21 PM
To: 'Fugere, Raymond G.'
Subject: RE: NERC Alert Advice Letters

Mr. Fugere,

The tower installation years for the lines are:

Contra Costa-Moraga #1 & 2 230kV – 1950

Monta Vista – Hicks 230kV – 1957

Saratoga – Vasona 230kV – 1957

I will send the tables in a separate email.

Thanks,

Meredith Allen

415-828-5765 (cell)

From: Allen, Meredith

Sent: Friday, December 21, 2012 12:16 PM

To: Fugere, Raymond G.

Subject: RE: NERC Alert Advice Letters

Mr. Fugere,

Charles Mee is assigned to the advice letters. In addition to Charles, we have also been discussing with Molly Sterkel.

I've checked in with the team and they are pulling together the information on segment heights and the installation dates. I will send to you as soon as I have it.

Thank you so much for looking into this issue.

Meredith Allen

415-973-2868 (office)

415-828-5765 (cell)

From: Fugere, Raymond G. [<mailto:raymond.fugere@cpuc.ca.gov>]

Sent: Friday, December 21, 2012 11:08 AM

To: Allen, Meredith

Subject: RE: NERC Alert Advice Letters

Ms. Allen:

Thank you for a copy of the advice letters. I have a couple of questions:

- Who in the Energy Division is PG&E in contact with?
- Does PG&E have a table or other document that shows the current height of the Transmission line segments, the current requirements (with code section) and what it plans to raise the segments to?
- If PG&E does have a table (or similar document) would it be possible to send that to me?
- When were these towers originally installed?

I just want to make sure that I understand the issue fully before talking to the Energy Division.

Thank you for your time and attention.

Raymond G. Fugere, P.E.

Program & Project Supervisor

320 W. 4th Street, Suite 500

Los Angeles, CA 90013

Office (213) 576-7015

From: Allen, Meredith [mailto:MEAe@pge.com]
Sent: Monday, December 17, 2012 6:28 PM
To: Fugere, Raymond G.
Subject: NERC Alert Advice Letters

Mr. Fugere,

PG&E filed advice letters in June 2012 providing notice of construction on the Contra Costa-Moraga 230 kilovolt (kV) Transmission Line (AL 4058-E) and the Saratoga-Vasona 230 kV Transmission Line in the Town of Los Gatos and the Monta Vista-Hicks 230 kV Transmission Line in the Cities of Saratoga and Cupertino (AL 4066-E).

PG&E has identified discrepancies along these lines. On Contra Costa-Moraga, PG&E plans to raise the height of 14 lattice steel towers and do one dead end conversion to address the discrepancies. On Saratoga-Vasona and Monta Vista-Hicks, PG&E plans to raise four lattice steel towers to address these discrepancies.

We are currently working with Energy Division on questions they have concerning the need for completing the work. We submitted supplements on Friday to provide further explanation, which are attached. As we discussed, this work will be conducted as a result of our transmission line assessment in response to the NERC Alert after Executive Director Resolutions are issued on the Advice Letters.

Please let me know if you would like additional information.

Thank you,

Meredith Allen

415-973-2868 (office)

415-828-5765 (cell)

PG&E is committed to protecting our customers' privacy.
To learn more, please visit <http://www.pge.com/about/company/privacy/customer/>