

From Structure	To Structure	Controlling Weather Case	Clearance Infraction (ft)	Description	G.O. 95 Required Clearance (ft.)	PG&E Required Clearance (ft.)	Existing Minimum Clearance (ft.)	New Minimum Clearance (ft.)
1/9	1/10	194°F Bare	-3.80	Ground	27	28	23.2	39
2/17	3/18	194°F Bare	-2.14	Ground	27	28	24.8	39
3/18	3/19	194°F Bare	-1.57	Ground	27	28	25.4	28.63
4/23	4/24	194°F Bare	-3.59	Ground	27	28	23.4	34
4/26	5/27	194°F Bare	-3.22	Ground	27	28	23.7	37.7
5/27	5/28	194°F Bare	-0.81	Ground	27	28	26.1	35.5
11/58	12/59	194°F Bare	-2.17	Ground	27	28	24.8	39.65
18/88	18/89	194°F Bare	-5.25	Wire	10	13.5	4.75	15.2