

From Structure	To Structure	Controlling Weather Case	Clearance Infraction (ft)	Description	G.O. 95 Required Clearance (ft.)	PG&E Required Clearance (ft.)	Existing Minimum Clearance (ft.)	New Minimum Clearance (ft.)
1/9	1/10	194°F Bare	-4.77	Ground	27	28	22.2	37.9
2/12	2/13	194°F Bare	-1.35	Ground	27	28	25.6	34.3
4/23	4/24	194°F Bare	-6.46	Ground	27	28	20.6	30.6
4/26	5/27	194°F Bare	-5.37	Ground	27	28	21.6	36.8
9/50	10/51	194°F Bare	-3.82	Ground	27	28	23.2	34.5
11/58	12/59	194°F Bare	-2.17	Ground	27	28	24.9	36.9
12/62	13/63	194°F Bare	-3.10	Ground	27	28	23.9	28
13/67	13/68	60°F Bare	-0.46	Ground	30	31	29.5	35.2
18/88	18/89	194°F Bare	-5.04	Wire	10	13.5	4.96	15.33
26/125	26/126	194°F Bare	-0.39	GROUND	27	28	26.6	36.8